
NOTES

This drawing is to be read in conjunction with drawing Nos. F2505/01-25



Section

Plan

Nominal Diameter (mm) DN	Maximum Effective Rocker Pipe Length (m)
150 - 600 601- 750 over 750	0.6 1.0 1.25

Nominal internal diameter of largest pipe in manhole (mm)	Minimum nominal internal dimension of manhole (mm)
< 375 375 - 450 500 - 700 750 - 900 > 900	1200 1350 1500 1800 Pipe Ø + 900


In accordance with SFA 7th Edition (Note: Clause References are to SFA 7th Editon)
Maximum depth from cover level to soffit of pipe 3.0m

Typical Adopted Manhole Detail - Type 2

Rigid pipes built into manhole should have a flexible joint as close as feasible to the external face of the structure and the length of the next rocker pipe should be as shown.

Nominal diameter (mm)	Maximum effective length (m)
150 - 600	0.6
601 - 750	1.00
over 750	1.25


All pipes entering the bottom of the manhole to have soffits level.



Sectional Plan


In accordance with SFA 7th Edition

Typical Arrangement of Pipe Junctions Within Adopted Manholes




Section

Typical Manhole Type 1/2 Catchpit Detail



Section



Plan

Nominal Diameter (mm) DN	Maximum Effective Rocker Pipe Length (m)
150 - 600 601- 750 over 750	0.6 1.0 1.25

Nominal internal diameter of largest pipe in manhole (mm)	Minimum nominal internal dimension of manhole (mm)
< 375 375 - 450 500 - 700 750 - 900 > 900	1200 1350 1500 1800 Pipe Ø + 900

In accordance with SFA 7th Edition (Note: Clause References are to SFA 7th Editon)
Maximum depth from cover level to soffit of pipe 3.0m

SW3 - Typical Adopted Manhole Detail - Type 2 Special Flow Control MH

REV	DESCRIPTION	DATE
-	Issued For Approval	02/02/17

abmh
Consulting Civil & Structural Engineers
1 The Grove, Felpham, Bognor Regis, West Sussex PO22 7EY
Alun Mob: 07809 550090 / Mark Mob: 07761 950000
Email: info@abmh.co.uk / Web: www.abmh.co.uk

PROJECT	CRL LITTLEHAMPTON 38-40 EAST STREET & 35 FITZALAN ROAD LITTLEHAMPTON, BN17 6AN
DRAWING	DRAINAGE DETAILS Sheet 3 of 3
Prj No.	F2505/08 REV -
SCALE	1:20 DATE FEB 17 INITIAL MH CHKD -

This drawing is produced using Autocad: Only written dimensions are to be respected

ARUN DISTRICT COUNCIL LU1317/DOC