

From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 05 May 2021 14:38

To: Andrew Wood <Andrew.Wood@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: 125 Bayford Road Littlehampton BN17 5HW - LU/131/21/DOC

Planning Application Reference: LU/131/21/DOC

Proposal: Approval of details reserved by condition imposed under ref LU/13/21/PL relating to Condition Nos 3 - covered & secure cycle parking and 4 - electric vehicle charging space.

Address: 125 Bayford Road Littlehampton BN17 5HW

Dear Andrew,

Having reviewed the document entitled 'Proposed site plan and cycle storage Dwg No 2445-01' I can confirm the plan confirms the location of an electric vehicle charging point. Further information is required to include details of the proposed Electric Vehicle Charging point. The information should include technical specification from the manufacturer confirming that the charge point power output is 7kW in accordance with government guidance document 'Electric Vehicle Charging in Residential and Non-Residential Buildings' (July 2019) [produced by DfT], available from: [Electric vehicle charging in residential and non-residential buildings \(publishing.service.gov.uk\)](https://www.publishing.service.gov.uk/government/uploads/system/uploads/attachment_data/file/824442/electric_vehicle_charging_in_residential_and_non-residential_buildings.pdf)

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

