



From: Chima Umunnakwe <Chima.Umunnakwe@arun.gov.uk>

Sent: 05 July 2021 15:13

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Cc: Anita Gardner <Anita.Gardner@arun.gov.uk>

Subject: LU/136/21/PL

Dear Planning,

I have reviewed the above application reference, and I can advise that Environmental Health have no adverse comments to make in relation to the proposed scheme subject to the following consideration.

Plant Noise condition

Prior to the first use of the premises, details of any plant (including ventilation, refrigeration and air conditioning) and / or ducting system to be used and the method of control of noise and vibration of this plant shall be submitted to and approved in writing by the Local Planning Authority. The development shall be carried out in accordance with the approved details. The scheme shall ensure that the noise and vibration generated at the boundary of any noise sensitive property shall not exceed Noise Rating Curve: NR35 as defined within Table B.1: Noise Rating Values of BS 8233:2014.

The equipment installed and commissioned shall be maintained in a condition and operated in compliance to the approved scheme whenever it is operation so that it does not exceed NR35 as described above, whenever it's operating. After installation of the approved plant, no new plant or ducting system shall be used without the prior written consent of the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Construction – Small Developments

Prior to the commencement of the development hereby approved, a scheme to demonstrate that the construction phase of the development will conform with 'Arun District Council Construction Code of Practice: For small developments in Arun', shall be submitted to the Local Planning Authority for approval. The works specified in the approved scheme shall then be carried out in accordance with the approved details.

'Arun District Council Construction Code of Practice: For small developments in Arun' is available from:
[download.cfm \(arun.gov.uk\)](#)

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Construction hours

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

[In addition to these hours of working, the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of The Adopted Arun Plan 2011 – 2031

Regards

Chima Umunnakwe
Environmental Protection Officer
Technical Services

T: 01903 737336

E: chima.umunnakwe@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Due to the current pandemic, work is being prioritised according to public safety risks and you may not receive an immediate response to your email. Wherever possible we will endeavour to respond within 7 working days.

The Environmental Health Team in particular are focused on supporting COVID-19 compliance, and other services may be limited or delayed. Further details of our current service levels can be found at: <https://www.arun.gov.uk/service-status>

If you are making contact for advice or to register a new request for service, including enquiries about COVID-19, food safety, noise or pollution, you can register these directly on-line at <https://eh.arun.gov.uk/>