

[REDACTED]

From: Joanne Lewis <Joanne.Lewis@arun.gov.uk>
Sent: 22 June 2022 12:31
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: RE: Planning Consultation on: LU/149/22/PL

I refer to the above planning application for a cover to the roof terrace and first floor extension.

I have no objections to this proposal, however the applicant should note that to comply with food hygiene regulations there must be adequate separation between WC rooms and rooms used to store or prepare food. Rooms used for open food preparation will also require adequate hand washing facilities and drainage as well as being generally suitable for the storage or preparation of food depending on what purpose the new room is to be used for. Further advice can be given to the business, for example, on the internal layout of the food premises. If the applicant would like further advice please contact the Environmental Health Service on [REDACTED]

<https://www.arun.gov.uk/food-premises-registration>

Joanne Lewis

My working pattern is usually between 09.30 and 14.45 Tuesday – Friday.

Joanne Lewis
Senior Environmental Health Officer,
Environmental Health

T: 01903 737666
E: joanne.lewis@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

I occasionally send emails outside of working hours. If this arrives outside your normal working hours, please do not feel compelled to respond immediately.

Sign up to our newsletter [here](#)



Business Support during Coronavirus click [here](#)

From: Planning.Responses <Planning.Responses@arun.gov.uk>
Sent: 17 June 2022 08:19
To: EHPlanningConsultations <EHPlanningConsultations@arun.gov.uk>
Subject: Planning Consultation on: LU/149/22/PL

To: Environmental Health - Planning consultation

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission

Application No: LU/149/22/PL
Registered: 16th June 2022
Site Address: Promenade Shelter Sea Road Littlehampton BN16 2NA
Grid Reference: 503973 101344
Description of Works: Cover to existing roof terrace and first floor extension to provide toilets and store. This site is in CIL Zone 5 (Zero Rated) as other development.

The Council have received the above application.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 21st July 2022 . You can also monitor the progress of this application through the Council web site:

<https://www.arun.gov.uk/planning-application-search>

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website

<https://www.arun.gov.uk/development-plan> as can information on what comments we can consider

<https://www.arun.gov.uk/planning-application-comments>

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: <https://app.planninginspectorate.gov.uk/> but they will protect personal details.

In the absence of a reply within the period stated, I shall assume that you have no observations to make

Yours sincerely

Mrs A Gardner

Planning Officer- Arun District Council

Telephone: 01903 737529

Email: Anita.Gardner@arun.gov.uk

PLCONSULT (COB) 2020