



Neil Crowther

From: Fiona Fitzgerald
Sent: 22 July 2014 10:23
To: Neil Crowther
Subject: LU/157/14/DOC

Dear Neil,

With regard to Condition 17, there is insufficient information provided to discharge this condition.

Specifically:

- v) measures to control the emission of dust and dirt during construction – this has focussed only on wheel washing and road sweeping, no mitigation measures to prevent or reduce dust emitted from the site have been provided.
- vii) Noise and Vibration Controls – this appears to have been omitted completely.

Please ask the applicant to address these issues.

Regards

Fiona Fitzgerald

Fiona Fitzgerald | Environmental Health Officer, Environmental Health Department, Arun District Council | Location: Third Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.