

Neil Crowther

From: Paul Scamans
Sent: 28 July 2014 14:57
To: Neil Crowther
Subject: RE: LU/158/14/DOC

Hi Neil,

The document demonstrates more than a 10% improvement over 2010 Approved Document L standards (carbon emissions reduced by more than 10%). All of the properties will be subject to air leakage tests. The planning condition does not set a Sustainable Design code standard, or BREEAM standard for the dwelling.

This would therefore appear to satisfy the planning condition.

Kind regards

Paul

From: Neil Crowther
Sent: 28 July 2014 11:52
To: Building Control Staff
Subject: LU/158/14/DOC

Hi,

I sent a consultation to Building Control on LU/158/14/DOC on 26 June. The application is for energy saving strategy at Courtwick and, as Jo Allat is no longer here, I don't know where else to get some advice on this.

Can I have a chat with whoever has picked this up?

Thanks, Neil

Neil Crowther | Strategic Development Manager, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road,
Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

