

From: Martyn White <Martyn.White@arun.gov.uk>
Sent: 09 February 2022 18:25
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: LU/15/22/DOC

LU/15/22/DOC

Winterton Lodge Goda Road Littlehampton BN17 6SY

Approval of details reserved by condition imposed under LU/102/21/L relating to condition 3-proposed materials.

The condition relates purely to the proposed materials, as opposed to the appearance of the proposed walling which is unfortunate. I do not appear to have been consulted on the original application which does not help with the determination of this application. Ideally, the proposed mortar mix will be based on an assessment of that in the existing wall. If this is the case, the mortar and other materials are acceptable, and the condition can be discharged.

Martyn White
Principal Conservation Officer,
Planning Services



Please note: I work on Conservation for half of the working week (all day Monday and Friday and Tuesday Afternoons)

T: 01903 737717
E: Martyn.White@arun.gov.uk or Conservation.officer@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

To register to receive notification of planning applications in your area p



<https://www1.arun.gov.uk/planning-application-finder>