

From: Amanda Scholes on behalf of Planning.Responses
Sent: 17 July 2017 11:21
To: Planning Scanning
Subject: FW: LU/160/17/DOC - 131-135 Arundel Road

From: David Easton
Sent: 17 July 2017 10:57
To: Planning.Responses
Subject: FW: LU/160/17/DOC - 131-135 Arundel Road

Please upload as a consultation response from Environmental Health

From: Matthew Kennett
Sent: 17 July 2017 10:43
To: David Easton
Subject: LU/160/17/DOC - 131-135 Arundel Road

Hi David,

Condition 11 can be passed, but for Condition 13 to be passed further validation work and reporting is required for the clean capping layer and hydrocarbon resistant membrane that was proposed previously in the Remediation Method Statement (A10706/RMS/1.0).

Thanks

Matthew Kennett
Snr. Pollution Officer
Environmental Health Department
01903 737696 (direct line)
Arun Civic Centre, Maltravers Road, Littlehampton BN17 5LF
<http://www.arun.gov.uk/eh>

