

Environmental Health Consultation Response

To	Hebe Smith
Date	12-08-2026
Planning Ref	LU/164/26/PL
Site Description	Littlehampton Caravan Park Mill Lane Littlehampton West Sussex BN17 7PH
Date of Application	2026-07-31 00:00:00
Category	Application
Recommendation	No Objection No Objection – with condition Objection Holding Objection

EH Comments:

No objection, recommended light control condition (see below).

Condition Recommended:

LIGHT01

Prior to the use of any part of the development, full details of all new external lighting, including type of light appliance, the height and position of fitting, predicted illumination levels and light spillage, shall be submitted to and approved in writing by the Local Planning Authority. The scheme should seek to conform with the recommendations of the Institute of Lighting Professionals (ILP) 'Guidance Notes for the Reduction of Obtrusive Light' (GN01:2011) and:

- a) identify those areas/features on site that are particularly sensitive for bats and that are likely to cause disturbance in or around their breeding sites and resting places or along important routes used to access key areas of their territory, for example, for foraging
- b) show how and where external lighting will be installed through provision of appropriate lighting contour plans and technical specifications so that it can be clearly demonstrated that areas to be lit will not disturb or prevent the above species using their territory or having access to their breeding sites and resting places.

All external lighting shall be installed in accordance with the specifications and locations set out in the scheme and maintained thereafter in accordance with the scheme. Under no circumstances should any other external lighting be installed without prior written consent from the Local Planning Authority.

Reason: In the interests of the amenities of the area, the site's biodiversity (particularly in respect of bats), the interests of minimising crime, the interests of road safety and to minimise unnecessary light spillage outside the development site in accordance with Arun Local Plan policies QE SP1, QE DM2, T SP1 and ENV DM5.

[REDACTED]

From: Elaine Walby on behalf of Planning.Responses
Sent: 17 August 2026 09:52
To: Planning Scanning
Subject: FW: LU/164/26/PL - Littlehampton Caravan Park, Mill Lane, Wick BN17 7PH
Attachments: LU16426PL.docx

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Our priorities...

 Improving the wellbeing of Arun	 Delivering the right homes in the right places	 Supporting our environment to support us	 Fulfilling Arun's economic potential	 Our core foundations	 
---	--	--	--	---	--

Connect with us: [Facebook](#) | [X](#) | [Instagram](#)

From: Kate Giddings <kate.giddings@arun.gov.uk>
Sent: 12 August 2026 09:56
To: Hebe Smith <Hebe.Smith@arun.gov.uk>
Cc: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: LU/164/26/PL - Littlehampton Caravan Park, Mill Lane, Wick BN17 7PH

Dear Hebe,

I hope you are well.
Please find attached EH's response to the above consultation.

Many thanks,

Kate.

Kate Giddings
Senior Environmental Health Officer, Environmental Health

Working days: Tuesday, Wednesday and Thursday.

T: 01903 737586

E: kate.giddings@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Road
Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



Our priorities...

 Improving the wellbeing of Arun	 Delivering the right homes in the right places	 Supporting our environment to support us	 Fulfilling Arun's economic potential	 
---	--	--	---	--