

From: Laura Gibbons
Sent: 31 May 2019 16:00
To: Planning.Responses
Cc: Juan Baeza
Subject: RE: Planning Consultation on LU/167/19/DOC

Engineers Comments Regarding Condition 3- surface water drainage

I recommend that condition 3 is discharged based on the supplied information.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 31 May 2019 15:37
To: Land Drainage
Subject: Planning Consultation on LU/167/19/DOC

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION LU/167/19/DOC
NO:

Registered: 22-MAY-19
Site Address: Castleview Storage Castleview Storage, Old Mead Road
Littlehampton BN17 7PU

Description of Works: Approval of details reserved by condition imposed under ref LU/131/18/PL relating to Condition No 3 - proposed surface

water drainage scheme.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 14th June 2019.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mr J Baeza who can be contacted on telephone number 01903 737765.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
