

[REDACTED]

[REDACTED]

From: Kate Giddings [REDACTED]
Sent: 25 September 2019 11:50
To: Anita Gardner <Anita.Gardner@arun.gov.uk>
Subject: RE: LU/171/19/PL - 1 Lineside Way, Littlehampton

Dear Anita,

Thank you for your e-mail.

The site is located in proximity to residential dwellings and EH has a history of complaints regarding noise and odour emissions from the business. EH would therefore be minded to object to 24/7 operation until an acoustic assessment has been undertaken to determine the impact of noise arising from the site and the results of the assessment and details of any mitigation measures submitted to and approved in writing by this Department.

Noise from commercial premises should be controlled, such that the noise rating level (L_{Ar,Tr}) emitted from the development does not exceed the background noise level (L_{A90,T}), by more than 3dB. All measurements shall be defined and derived in accordance with BS 4142:2014. It is recommended that the assessment is conducted by a suitably qualified, independent consultant; we are able to provide a list of acoustic consultants based in East and West Sussex.

Many thanks,

Kate.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road,
Littlehampton, West Sussex, BN17 5LF
Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk



From: Anita Gardner <Anita.Gardner@arun.gov.uk>
Sent: 24 September 2019 16:39
To: Kate Giddings <kate.giddings@arun.gov.uk>
Subject: RE: LU/171/19/PL - 1 Lineside Way, Littlehampton

Kate,

I have now looked at the planning application form which states they are requesting a variation to allow 24 hour use 7 days a week to accord with running of all parts of the business.

Please can you let me know if you would object to this even if the suggested acoustic condition is imposed?

Thanks

Anita

[Anita Gardner](#) | Principal Planner, Directorate of Place, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk



From: Kate Giddings <kate.giddings@arun.gov.uk>
Sent: 24 September 2019 16:09
To: Anita Gardner <Anita.Gardner@arun.gov.uk>
Subject: RE: LU/171/19/PL - 1 Lineside Way, Littlehampton

Super, thanks very much 😊

[Kate Giddings](#) | Senior Technical Officer, Environmental Health, [Arun District Council](#) | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF

Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk



From: Anita Gardner <Anita.Gardner@arun.gov.uk>
Sent: 24 September 2019 16:06
To: Kate Giddings <kate.giddings@arun.gov.uk>
Subject: RE: LU/171/19/PL - 1 Lineside Way, Littlehampton

Thanks Kate I couldn't find the e-mail . I will go back to the agent now and seek clarification of the hours

Regards

Anita

Anita Gardner | Principal Planner, Directorate of Place, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk
Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

From: Kate Giddings <kate.giddings@arun.gov.uk>
Sent: 24 September 2019 15:56
To: Anita Gardner <Anita.Gardner@arun.gov.uk>; EH Planning Consultations
[REDACTED]
Subject: RE: LU/171/19/PL - 1 Lineside Way, Littlehampton

Dear Anita,

Thank you for your e-mail.
Please find attached my response of 7th June – I don't think I've received anything subsequent to this...

Many thanks,

Kate.

Kate Giddings | Senior Technical Officer, Environmental Health, [Arun District Council](#) | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF
Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk
Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

From: Anita Gardner <Anita.Gardner@arun.gov.uk>
Sent: 24 September 2019 15:51
To: EH Planning Consultations [REDACTED]
Subject: LU/171/19/PL - 1 Lineside Way, Littlehampton

A consultation was sent on 28-05-2019 and I am still awaiting a response. Please can you advise who the case officer is so that I can chase for a reply
Thanks

Anita Gardner | Principal Planner, Directorate of Place, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk
Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.