

From: Kate Giddings
Sent: 07 June 2019 17:12
To: Anita Gardner; Anna Appleton
Subject: LU/171/19/PL - Unit 1, Lineside Way, Littlehampton, BN17 7EH

Good afternoon,

In relation to the above application, before EH is able to provide formal comments, could the applicant please confirm the proposed hours of operation?

I understand the application is to remove the restriction on the existing hours of operation but it is not clear whether the business intends to operate 24 hours a day, seven days a week.

It is also recommended that the following condition is applied to any approval, with a focus on night-time noise disturbance:

- The amended hours of operation hereby permitted shall not commence until an acoustic assessment has been undertaken to determine the impact of noise arising from the site and the results of the assessment and details of any mitigation measures submitted and approved in writing by the Local Planning Authority. Noise from commercial premises should be controlled, such that the noise rating level ($L_{A,T,r}$) emitted from the development does not exceed the background noise level ($L_{A90,T}$), by more than 3dB. All measurements shall be defined and derived in accordance with BS 4142:2014. The approved measures shall be implemented before the amended hours are brought into use and thereafter be maintained in accordance with the approved details. **Reason:** *To protect the amenity of local residents in accordance with Policy QE DM1 of the Adoption Arun Local Plan 2011 – 2031.*

Many thanks,

Kate.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF

Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.