

From: Paul Cann
Sent: 28 July 2017 10:50
To: Planning.Responses
Subject: RE: Planning Consultation on LU/177/17/DOC

Southern Water should be consulted in respect to condition no.6.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

Paul Cann | Senior Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37819 | External: +44 (0) 1903 737819 | Fax: +44 (0) 1903 716019 | E-mail: Paul.Cann@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 21 July 2017 12:04
To: Paul Cann
Subject: Planning Consultation on LU/177/17/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION LU/177/17/DOC

NO:

Registered: 31-MAY-17
Site Address: Littlehampton Swimming & Sports Centre Sea Road
Littlehampton BN16 2NA

Description of Works: Application for approval of details reserved by condition imposed under planning permission LU/314/16/PL relating to condition No. 3 (Landscaping scheme), 4 (Habitat mitigation strategy), 6 (Foul & Surface water sewerage disposal), 10 (Details of plant & equipment), 14 (Details of kitchen extract system & type of cooking to be undertaken in the facility) & 15 (External lightings scheme)

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 4th August 2017.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number 01903 737529.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
