

From: Kate Giddings <kate.giddings@arun.gov.uk>

Sent: 20 July 2021 15:44

To: Michael Eastham <Michael.Eastham@arun.gov.uk>

Cc: Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: LU/183/21/DOC - Phase 2b, Hampton Park, Toddington Lane, Littlehampton, BN17 7PL

Good afternoon,

In relation to the above and having reviewed Parking Strategy Plan (drawing no. 545_PL_105), please may the developer demonstrate that 100% of all units with a driveway or garage and that 20% of all other units will have an active EV charging point? It is not clear from the submission where the numbers apply; there are 103 allocated parking spaces, 11 garage spaces and 10 visitors spaces (plus eight are motorcycle spaces). Every parking provision within a garage or on a driveway will need an active EV charging point, as will 20% of the remaining spaces. The provision of 28 active charging points (19 active charging points to fulfil the driveway/garage allocation and nine active charging points to serve the remaining 20% of dwellings) does not seem to tally.

Many thanks,

Kate.

Kate Giddings
Senior Technical Officer
Environmental Health

T: 01903 737586

E: kate.giddings@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)
Business Support during Coronavirus click [here](#)

