

Persimmon Homes Thames Valley
Persimmon House
Knoll Road
Camberley
GU15 3TQ

Date: 1st November 2021

Please ask for: Michael Eastham
Tel: 01903 737772

Your Ref:

Our Ref: LU/184/21/DOC

Dear Miss Harris,

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Approval of details reserved by condition imposed under ref LU/47/11 relating to Condition Nos 10 - surface water drainage, 12 - discharge of any flows to watercourses, 13 - foul drainage, 15 - tree protection, 19 - ecological survey, 20 - ecological management plan, 21 - ecological management plan for construction phase, 31 - renewable energy, 33 - contamination and 40 - archaeology.

Phase 2B Hampton Park Toddington Lane Littlehampton BN17 7PL

Notification regarding the above application:

Condition Number 10

No development shall begin until a fully detailed surface water drainage scheme for that phase of the development, based on sustainable drainage principles and designed in accordance with the SUDS strategy for the whole development, has been submitted to and approved in writing by the Local Planning Authority. It should be demonstrated how each detailed scheme will contribute to delivering, and link into, the surface water drainage strategy for the site as a whole.

- The SUDS shall be designed to attenuate the 1 in 100 year storm event (plus climate change allowance of 30% in accordance with DEFRA's National Standards for Sustainable Drainage Systems).
- No infiltration of surface water drainage shall occur within ground affected by contamination unless suitable remediation is undertaken.
- Each detailed scheme should include a timetable for its implementation; and provide a management and maintenance plan in the form of a site specific Maintenance Manual for the SUDS system for the lifetime of the development. This shall include the arrangements for adoption by any public authority or statutory undertaker or details of the financial management of the scheme throughout its lifetime.

Elements of the scheme serving any particular phase shall subsequently be implemented in accordance with the approved details (unless otherwise agreed with the Local Planning Authority) prior to the occupation of any dwellings in that phase and no building in that phase of the development shall be occupied until the surface water drainage scheme has been fully implemented in accordance with the approved details.

Reason: To ensure that the proposed development is satisfactorily drained to prevent the increased risk of flooding, and improve and protect water quality, habitat and amenity, and ensure future maintenance of these in accordance with national guidance and policies GEN7, GEN9 of the Arun District Local Plan.

Decision:

Arun District Council have decided to **REFUSE details reserved by condition for the following reasons:**

The information submitted regarding Condition 10 imposed on outline planning permission LU/47/11: relating to a fully detailed surface water drainage scheme at Phase 2B (also referred to as Phase 4) Hampton Park is refused and the condition is not discharged.

Further details on the surface water drainage scheme design are required to evidence that flood risk on site is safely managed and the development will not result in increased flood risk off site. Currently proposals are insufficient to demonstrate compliance with paragraphs 167 and 169 of the National Planning Policy Framework (2021), WSCC policy for the management of surface water policies 1-6, and Policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning