

Nicola Spencer

From: Eve Hearsey
Sent: 03 August 2010 12:26
To: Nicola Spencer; Lisa Coney
Subject: FW: East Beach Cafe - LU/189/10 - Copy of our comments

Dear Nicola/Lisa

Please could this consultation response be scanned for the above application. Ta.

Regards

Eve E Hearsey
Area Team Leader
Development Control - East

From: John Green
Sent: 03 August 2010 11:21
To: Eve Hearsey
Subject: East Beach Cafe - LU/189/10 - Copy of our comments

From: Graham Evans
Sent: 22 July 2010 16:13
To: Planning.Responses
Subject: LU/189/10

Environmental Health have not received a consultation on this application (yet?) I would nevertheless comment as follows.

This Department has received complaints from members of the public concerned that lighting at this premises shines horizontally along the promenade into the eyes of pedestrians. This has not been addressed in the application and I would draw the applicants attention to the attached ILE Guidance.

In particular, glare should be kept to a minimum by ensuring that the main beam angle of all lights directed towards any potential observer is maximum 70 degrees (from the vertical). Also that lighting equipment should be specifically designed to minimise the upward spread of light near to and above the horizontal.

The applicant is requested to consult a professional lighting designer and provides appropriate details to demonstrate that the proposed exterior lighting installation meets the obtrusive light limitations recommended for Environmental Zone E2.

Graham Evans
Senior Environmental Health Officer
Arun District Council
01903 737694