FDKS FD30 SELFCLOSING FIRE DOOR FITTED WITH SIGN FIRE DOOR KEEP SHUT

FDKL FD30 FIRE DOOR FITTED WITH SIGN FIRE DOOR KEEP LOCKED

FE FIRE EXIT SIGN

BREAK GLASS AND SIGN

2kg CARBON DIOXIDE EXT. AND SIGN

3lt. WATER EXT.

E EMERGENCY LIGHT

FIRE CONTROL PANEL

(S) SMOKE DETECTOR

(A) DOOR FITTED WITH PANIC BAR AND SIGN PUSH BAR TO OPEN

(T) DIGITAL LOCK TURN TO OPEN

MANOR HOUSE GROUND FLOOR PLAN
SHOWING PLAN OF STORE 26
STORE 26 CHANGING TO DDA TOILET.

ADC OFFICES
COMP SERVER 025
STORE 024
STORE 025A
STORE 026
WC 028
FDKS
TEA 027
LOCAL STUDIES/OFFICE 029
020
STORE 023
022
OFFICE 021
FE
FDKS FD60
019
LTC RECEPTION 018
GALLERY 5 016
GALLERY 4 014
TEMPORARY GALLERY 013
SHOULD BE SD
STORE
SHOULD BE FDKL
DIS. WC 009
WC 010
WC 010A
SHOULD BE SD?
011
FE ILLUMINATED
FDKS
008
SHOULD HAVE SIGN FIRE DOOR KEEP CLEAR
GALLERY 3 005
GALLERY 2 004
GALLERY 1 003
017
FD30S
MUSEUM RECEPTION 002
001

ARUN DISTRICT COUNCIL:LU/191/08/L