



Date/Tax Point: 6th June 2019

Dear Shaun

Re: 52 High Street, Littlehampton

Further to my recent site visit, I have pleasure in enclosing the following specification.

To Supplying and fitting 1 off 3800mm long x 1200mm deep x 600mm high stainless steel wall hung extraction canopy fabricated from 304 grade 0.9 DP1 stainless steel containing 7 off stainless steel baffle filters and 2 off LED canopy lights.

To Supplying and fitting stainless steel wall cladding to the rear and both side walls under the extraction canopy.

To Supplying and fitting 1 off plenum incoming air chamber with 2 off grilles terminating at the bottom front edge of the extraction canopy and ducted to the outside, through the outside rear wall with 4 metres of duct. This will connect to an incoming air fan filter box

Registered Office: 29 Cuckfield Crescent, Worthing, BN13 2ED
VAT Registration No: GB 197 5218 71
Company No: 10161846



The duct will then exit through the right rear wall of the building where it will turn vertically through 90° and connect to a 630mm diameter x 600mm long attenuator. We will then connect in a 630mm Helios Gigabox 3 phase fan. This fan will be mounted by means of cantilever brackets with anti-vibration mounts and will be isolated both in and out of the fan by flexible connections. The duct will then connect into another 630mm diameter x 600mm long attenuator.

The sound pressure case breakout for the above will be 42dBA with the sound pressure intake being 53dBA.

The duct will then rise to the top of the building in 630mm diameter spiral duct where it will terminate 1000mm above the gutter line with a 630mm high velocity jet cowl.

All the external duct including the attenuators, Helios Gigabox fan, spiral duct and jet cowl will be powder coated in terracotta.

We will also supply and fit an inverter speed controller for the extract fan and a speed controller for the incoming air fan.

The above will **exclude** all building work and electrical work.

If you have any queries or would like to discuss this specification further, please do not hesitate to contact [REDACTED]

Yours sincerely
for and on behalf of Sussex Catering Equipment (SCE) Ltd

[REDACTED]