

From: Anita Gardner
Sent: 28 August 2019 14:02
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: 22 Beach Road, Littlehampton.
Importance: High

Please scan as correspondence with agent

Anita Gardner | Principal Planner, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: David Pickford [REDACTED]
Sent: 28 August 2019 13:31
To: Anita Gardner <Anita.Gardner@arun.gov.uk>
Subject: FW: 22 Beach Road, Littlehampton.
Importance: High

Hello Anita

Following on from your attached email, for reference, please see email below from Scott Castle of Acoustic Associates (who produced the Noise Report submitted with applications LU/193/19/DOC & LU/194/19/DOC) to Carol Reynolds in response to comments made by Environmental Health.

The response has clarified issues and assumptions, as well as refuted specific objections, raised in Environmental Health's comments.

I trust that you will give ample time for these specific technical issues to be resolved with Environmental Health. Would you therefore like us to agree to a further extension of time for the applications?

I look forward to hearing from you soon.

Kind regards

David Pickford
Principal Planner


Pegasus Group

PLANNING | DESIGN | ENVIRONMENT | ECONOMICS | HERITAGE

Sutton Coldfield: 5 The Priory | Old London Road | Canwell | Sutton Coldfield | West Midlands | B75 5SH

City Centre: Colmore Place | 39 Bennetts Hill | Birmingham | B2 5SN

Birmingham | Bracknell | Bristol | Cambridge | Cirencester | East Midlands | Leeds | Liverpool | London | Manchester | Newcastle | Peterborough



www.pegasusgroup.co.uk


Pegasus Group is the trading name of Pegasus Planning Group Ltd (07277000) registered in England and Wales.

This email and any associated files, is intended for the exclusive use of the addressee only.

If you are not the intended recipient you should not use the contents, nor disclose them to any other person.

If you have received this message in error please notify us immediately. We have updated our Privacy Statement in line with the GDPR; please [click here](#) to view it.

Please consider the environment before printing this email message.



Pegasus Group's
National Charity 2019
[Click here to donate](#)

From: [REDACTED]

Sent: 23 August 2019 17:12

To: [REDACTED]

Subject: FW: 22 Beach Road, Littlehampton.

Importance: High

Darren Godfrey

Director

Southern Creations LTD

D&N Godfrey Services LTD

"This communication is confidential and may be legally privileged. If you are not the intended recipient, (i) please do not read or disclose to others, (ii) please notify the sender by reply mail, and (iii) please delete this communication from your system. Failure to follow this process may be unlawful

The information contained herein is strictly private and confidential to its recipients and may not be disclosed, copied, distributed or reproduced in whole or part, nor passed to any third party without the written consent from a director of Southern Creations Ltd and D&N Godfrey Services LTD

Thank you for your cooperation."

From: Scott Castle [REDACTED]

Sent: 23 August 2019 16:19

To: carol.reynolds@arun.gov.uk

Cc: Darren Godfrey

Subject: 22 Beach Road, Littlehampton.


Importance: High

Dear Carol

I trust that this finds you well.

I write further to the client providing me with your feedback on the AASL acoustic report dated 6th June 2019 for the above site.

The condensers would have run as part of the survey and are contained with the survey data.



A site photograph below shows the existing ductwork and importantly that the termination point is well away from the bedroom window and above eaves. Whilst present on site, Flat 3 was visited and subjectively listened to, before determining where to set up the various survey instruments. The rationale behind the selection of survey positions was already detailed within the report.



3. Reverberation Times

The reverberation times were measured in each of the locations where the surveys were undertaken. As noted from Table 3 in the report, the front bedroom in flat 2, was considerably higher in terms of reverberation than the smaller two bedrooms measured. As per Figure 4 of the report, the image displayed on the left hand side shows the laminated floor already laid.

When the bedroom is lived in and furnished with curtains, beds, pillows and duvets etc, the reverberation time will inevitably decrease and in this case a final reverberation time of 0.5s as was used in the calculations (This is what the Building Regulations state will be the average reverberation time for a furnished room). In this instance the correction used was 3dB as the empty surveyed rooms had an average reverberation time of 1s

Figures 6 and 7 in the report relate to Flat 1, however the references to 39 and 44dB relate to Flat 2, front bedroom, which is reported in Figure 10.

4. Relaxed Criteria from BS8233:2014

BS8233:2014 stated as follows in Note 7 under 7.7.2:

"Where development is considered necessary or desirable, despite external noise levels above WHO guidelines, the internal target levels may be relaxed by up to 5 dB and reasonable internal conditions still achieved."

The only concern within the report is that of the window facing Beach Road of Flat 2 for the daytime period. The night time period clearly meets the criteria of BS8233:2014 of 30dB $L_{Aeq, 8 \text{ hour}}$ measured over the 8 hour night.

Having applied the reverberation time adjustment for Flat 2, for the front bedroom and when compared against the complete 16-hour periods, the BS8233:2014 criteria is only exceeded by 1.3dB. It is therefore questionable as to how long an individual spends in their bedroom for the daytime 16-hour period. As per BS8233:2014 referenced above, a relaxation of 5dB will still allow reasonable internal conditions.

It is also relevant to consider that had we been engaged at the design stages earlier in the project, we could have provided a greater specification for windows and/or ventilation. However, the job was commissioned at the end of the build to measure the resulting internal soundscape, which does meet BS8233:2014.

5. Ventilation and Opening Windows

Whilst I appreciate the comments, the condition in question, which is condition 4 states as follows:

Prior to occupation of the flats hereby approved an acoustic report based upon actual readings on site, which demonstrates that the internal noise levels of the proposed residential units will conform to indoor ambient noise levels for dwellings as specified within BS8233:2014. Guidance on Sound Insulation and Noise Reduction for Buildings shall be submitted to and approved by the Local Planning Authority. The details shall include any mitigation measures which may prove necessary to be specified. Any works specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and retained thereafter to the satisfaction of the Local Planning authority.

Approved Document F which relates to ventilation states that where background ventilation is not present, it is best practice (as opposed to mandatory for a new build) to either install trickle vents or provide an alternative means of background ventilation, ie a partially opened window. A cracked open window, such as that in Flat 2 rear is in excess of the suggested criterion (5000mm²).

It is also relevant to note that there remains air entering the first and second floor properties, both living areas and bedrooms overlooking Beach Road from the fully operational chimney breasts and fireplaces which are present.

Notwithstanding the above, ventilation may easily be applied to the site, where it is required.

Opening the windows in the habitable rooms overlooking Beach Road will clearly elevate the internal soundscape, so an alternative approach is needed.

A recommended additional approach to allow fresh air and ventilation of the Beach road habitable rooms is to consider either through frame window vents or alternatively a through the wall ventilator. Both types of ventilator are extremely effective in providing the flow of air but attenuating sound as it passes through the wall space. Either requirement would need to be "acoustic ventilators". For obvious reasons, any ventilation point should not act as the weak part of the façade element and a rigorous calculation would determine the likely internal sound levels with either a frame mounted acoustic ventilator or through the wall acoustic ventilator applied.

In summary, I would welcome your feedback on the above areas and whether inclusion of these into the report is likely to lead to a favourable outcome for the client with a discharge of condition 4.


Kind regards



Scott Castle (MCIEH CEnv, MIOA)

Senior Consultant

Acoustic Associates Sussex Ltd.
& Sound Solutions Products Ltd.

Web: [REDACTED]

Address: Unit 8 Highdown House, Shoreham Airport, Shoreham-by-Sea, West Sussex, BN43 5PB.

Find us on the following social/business networks:



DISCLAIMER: The information in this email including any attached files is confidential and intended for the recipient(s) only. If you have received this email in error, please delete it. Acoustic Associates Sussex Ltd cannot be held liable for any misuse of the email and/or its related content.

While all emails sent are scanned for viruses before sending, it remains the responsibility of the recipient(s) to scan their incoming emails for viruses before downloading and/or opening the content.

To sign up to our email mailing-list to receive our latest news, information about new services and potential offers, please [Click Here](#)

To unsubscribe from our email mailing-list, please [Click Here](#)

To view our Privacy Policy, please [Click Here](#)

[REDACTED]

From: [REDACTED]
Sent: 06 August 2019 10:56
To: Anita Gardner <Anita.Gardner@arun.gov.uk>
Subject: RE: Application Refs LU/193/19/DOC & LU/194/19/DOC

Hello Anita

Thank you for the response. We are happy to agree to an extension of time for both applications.

I assume that they will be providing a combined response for both applications, given that they are inherently connected.

On the basis of the below, can we assume that the response will be published online w/c 19th August?

Kind regards

David Pickford
Principal Planner

Pegasus Group

PLANNING | DESIGN | ENVIRONMENT | ECONOMICS | HERITAGE

Sutton Coldfield: 5 The Priory | Old London Road | Canwell | Sutton Coldfield | West Midlands | B75 5SH

City Centre: Colmore Place | 39 Bennetts Hill | Birmingham | B2 5SN

[REDACTED] Liverpool | London | Manchester | Newcastle | Peterborough

  www.pegasusgroup.co.uk


Pegasus Group is the trading name of Pegasus Planning Group Ltd (01277500) registered in England and Wales.

This email and any associated files, is intended for the exclusive use of the addressee only.

If you are not the intended recipient you should not use the contents nor disclose them to any other person.

If you have received this message in error please notify us immediately. We have updated our Privacy Statement in line with the GDPR; please [click here](#) to view it.

 Please consider the environment before printing this email message.



From: Anita Gardner <Anita.Gardner@arun.gov.uk>
Sent: 06 August 2019 10:41
To: [REDACTED]
Subject: RE: Application Refs LU/193/19/DOC & LU/194/19/DOC

Dear David,

I haven't had a response from environmental health yet and can't determine the applications without their comments. I understand that the environmental health officer who will be responding is on leave for 2 weeks and I am away from the end of this week for 2 weeks. Hopefully her response will be received and scanned onto the web site in my absence. Can we therefore agree to an extension of time on both applications until 30-08-2019 to allow for response from environmental health and time for you to respond to those comments.

Regards
Anita

From: [REDACTED]
Sent: 06 August 2019 10:30
To: Anita Gardner <Anita.Gardner@arun.gov.uk>
Subject: RE: Application Refs LU/193/19/DOC & LU/194/19/DOC

Hello Anita

Further to the below, have you heard back from Environmental Health on the above applications? I cannot see any responses online.

I would be grateful if you could confirm, and allow us time to respond to any comments, if necessary. I'm conscious that the determination period for the applications has almost ran out with no responses received to date, therefore I trust that you would give us appropriate time to respond to any comments.

I look forward to hearing from you very soon.

Kind regards

David Pickford
Principal Planner

Pegasus Group

PLANNING | DESIGN | ENVIRONMENT | ECONOMICS | HERITAGE

Sutton Coldfield: 5 The Priory | Old London Road | Canwell | Sutton Coldfield | West Midlands | B75 5SH

City Centre: Colmore Place | 39 Bennetts Hill | Birmingham | B2 5SN

[REDACTED]

Birmingham | Bracknell | Bristol | Cambridge | Cirencester | East Midlands | Leeds | Liverpool | London | Manchester | Newcastle | Peterborough

  www.pegasusgroup.co.uk

Pegasus Group is the trading name of Pegasus Planning Group Ltd (07277000) registered in England and Wales.

This email and any associated files, is intended for the exclusive use of the addressee only.

If you are not the intended recipient you should not use the contents, nor disclose them to any other person.

If you have received this message in error please notify us immediately. We have updated our Privacy Statement in line with the GDPR; please [click here](#) to view it.

 Please consider the environment before printing this email message.



From: Anita Gardner <Anita.Gardner@arun.gov.uk>
Sent: 03 July 2019 09:37
To: [REDACTED]
Subject: RE: Application Refs LU/193/19/DOC & LU/194/19/DOC

Dear David,

I consulted Environmental Health on both applications on 19-06-2019 and will be processing them once responses are received. I would advise that replies are currently taking at least a month. If there are issues raised in the responses which can be resolved reasonably quickly I will come back to prior to determination.

Regards

Anita Gardner

[Anita Gardner](#) | Principal Planner, Directorate of Place, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: [REDACTED]
Sent: 02 July 2019 15:59
To: Anita Gardner <Anita.Gardner@arun.gov.uk>
Cc: [REDACTED]
Subject: Application Refs LU/193/19/DOC & LU/194/19/DOC

Hello Anita

I contact you in relation to the above applications for the discharge of condition 3 of planning permission reference LU/56/17/PL and discharge of conditions 3 & 4 of planning permission reference LU/321/17/PL to which I understand you are the case officer for both applications.

Can I get your thoughts on these applications and the associated submitted information please?

If you have any queries or concerns then please do not hesitate to contact either me or my colleague Catherine (cc'd into this email).

We look forward to hearing from you soon.

Kind regards

David Pickford
Senior Planner

Pegasus Group

PLANNING | DESIGN | ENVIRONMENT | ECONOMICS | HERITAGE

Sutton Coldfield: 5 The Priory | Old London Road | Canwell | Sutton Coldfield | West Midlands | B75 5SH

City Centre: Colmore Place | 39 Bennetts Hill | Birmingham | B2 5SN

[REDACTED] | Liverpool | London | Manchester | Newcastle | Peterborough



www.pegasusgroup.co.uk

Pegasus Group is the trading name of Pegasus Planning Group Ltd (07277000) registered in England and Wales. This email and any associated files, is intended for the exclusive use of the addressee only. If you are not the intended recipient you should not use the contents nor disclose them to any other person. If you have received this message in error please notify us immediately. We have updated our Privacy Statement in line with the GDPR; please [click here](#) to view it.



Please consider the environment before printing this email message



<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
