

Julie Grieves

From: Paul Cann
Sent: 08 July 2011 08:55
To: Planning.Responses
Cc: Stephen Daniels
Subject: FW: Planning Consultation on: LU/196/11/ at Littlehampton Wharf

Engineers comments:

Detailed drawings indicating the proposed/existing surface water drainage system are required for consideration. Whilst the Design & Access Statement describes the proposed/existing system, this is not sufficient information upon which to make comment.

No increase in flows to the existing surface water drainage system will be permitted. Any excess flow will need to be stored on site and the outflow restricted to an agreed rate.

Paul Cann
 Senior Engineer (Drainage & Coastal)

Paul Cann Senior Engineer (Drainage & Coastal), Engineering Services, Arun District Council Location: Second Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF Internal: 37819 External: +44 (0) 1903 737819 Fax: +44 (0) 1903 716019 E-mail: Paul.Cann@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Brian Holland
Sent: Thursday, July 07, 2011 1:28 PM
To: Paul Cann
Subject: FW: Planning Consultation on: LU/196/11/ at Littlehampton Wharf

Regards

*Brian Holland
 Engineering Services Manager
 Tel 01903 737815*

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 07 July 2011 11:31
To: Brian Holland
Subject: Planning Consultation on: LU/196/11/ at Littlehampton Wharf

To: Engineering Services Manager

NOTIFICATION FROM ARUN DISTRICT COUNCIL**TOWN AND COUNTRY PLANNING ACT 1990**

APPLICATION NO: LU/196/11/

Registered: 30-JUN-11
Site Address: Littlehampton Wharf Quayside Littlehampton BN17 5DN

Grid Reference:

Category: West Sussex Cons

Description of Works: Application under Regulation 3 of the Town & Country Planning General Regulations 1992 for the erection of one new storage bay and extension of existing bay for aggregate stocks - This application will be determined by WSCC

The Council have received the above planning application from West Sussex County Council. I shall be pleased to receive any observations you may wish to make.

[Click here to view documents available on our website](#)

Should you have any comments to make, these should be sent by replying to this email by 21st July 2011. You can also monitor the progress of this application through the Council web site:

[Click here to access West Sussex County Council web site and use search boxes to find the application.](#)

Please be aware that any comments you may make will be available on our website.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number 01903 737529.

Thanking you in anticipation

Regards
Planning Case Officer

consulteeReg3_email
