

From: Thomas Callaway
Sent: 15 March 2017 15:30
To: Planning.Responses
Subject: RE: Please find attached amendment on planning application Ref: LU/201/16/RES

Following my earlier comments and discussions with the consultant, I am satisfied that a drainage solution is possible. Detailed drainage design should be submitted as a DOC application showing that the 1 in 100 year storm plus climate change allowance is stored without flooding, with a half drain time of no more than 24 hours.

Regards

Tom Callaway

Thomas Callaway | Drainage & Coastal Engineer, Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre,
Maltrovers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716019 | E-mail: Thomas.Callaway@arun.gov.uk
Arun is Working in Partnership with Chichester District Council

Visit our web site at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 14 February 2017 17:04
To: Thomas Callaway
Subject: Please find attached amendment on planning application Ref: LU/201/16/RES

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION LU/201/16/RES
NO:

Registered: 27-JUL-16
Site Address: Windroos Nursery Worthing Road Littlehampton BN17 6LY

Grid Reference:

Category: Plan Applicat'n
Description of Works: Approval of reserved matters following outline consent
LU/229/10/ for appearance, landscaping, layout & scale for 84
No. dwellings

I am able to inform you that I have received an amendment to the above application dated 14th February 2017 relating to:- Amended description, various substitute plans and Highways update

[Click here to view the plans and documents](#)

If you should wish to make further representations as a result of this amendment you should click the link below and then click on 'comment on this application'. Please make any further comment by 16th March 2017.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

[Click here to make further comments](#)

The officer dealing with this application is Mr D Innes who can be contacted on telephone number 01903 737776.

Thanking you in anticipation

Planning Case Officer

pmac21_email
