



© This drawing and the building works depicted are the copyright of Banners Gate Ltd and may not be reproduced or amended except by written permission. No liability will be accepted for amendments made by other persons.

GENERAL NOTES

- This drawing is to be read in conjunction with relevant architectural and engineering drawings.
- Levels indicated in blocks are finished floor levels and are 100mm above adjacent finished ground levels unless otherwise shown.
- Levels of the existing road at the point of tie in with proposed site road must be checked prior to commencement of works.
- Any discrepancies between the details shown and actual on site conditions to be reported immediately to the engineer prior to commencement of works.
- The Contractor is to check and verify in conjunction with the Architects details all setting out points, building and site dimensions, levels and street levels and to ensure that they are fully compliant with the relevant building regulations and requirements of the site investigation report before work starts. The Contractor is to comply with all requirements with current building regulations, British Standard Specifications, Building Regulations and any other not specifically stated in this drawing.
- This drawing is not intended to show details of ground conditions or ground contaminants. Each area of ground relief upon to support any structure developed (including drainage) must be investigated by the Contractor any area of formation for said structures which do not accord with the anticipated conditions as described in the site investigation report are to be removed, refilled to the original ground level and the area shall be investigated by a suitable expert. Any earthworks shown indicate typical slopes for guidance only and should be investigated further by a suitable geotechnical report.
- Where existing trees are shown to be retained they should be subject to a full Arboricultural inspection for safety. All trees are to be planted so as to ensure they are a minimum of 5 metres from buildings and 3 metres from drainage and services, where applicable. A foundation is to be provided to accommodate the proposed tree planting, where applicable.

BUILDING DRAINAGE NOTES

- Building drainage shall comply with BS EN 752 2008 and the Building Regulations 2002 part H (updated 2015).
- All 600, 800 and 1000 are indicative and shall be confirmed on site using valid architectural plans. Any discrepancies must be reported to Engineer prior to commencement of site.
- All building drainage shall be 100mm diameter unless otherwise stated.
- All building drainage shall be clayware to BS EN 205 or UPVC to BS 4500 and BS EN 1401-1 with Class B or Class S bedding unless otherwise stated.
- All pipes under buildings without suspended floors shall have Class S bedding.
- Concrete protection shall be provided to all pipes with less than 200mm cover in pedestrian areas, to all pipes with less than 600mm cover in driveway areas and to all pipes with less than 1000mm cover in road or private driveway areas. Where concrete around a specified facility of joints is to be maintained by using compressible foam, the foam shall be replaced at each joint.
- Where a pipe passes through a wall an opening is to be formed to give at least 50mm clearance around the pipe. Backfill cover shall be supported by a concrete slab. The slab shall be 100mm thick and shall be supported by a concrete slab. The slab shall be 100mm thick and shall be supported by a concrete slab.
- Where a pipe trench is within 1m of a building, the pipe is to be protected with concrete protection and the trench filled with concrete up to the level of the ground surface.
- Where the formation of a pipe trench is above original ground level it is to be made up with well compacted D17 Type 2 material.
- Inspection chambers located within garages are to have double wall built down covers.
- All private drives which fall towards a public highway and exceed two parking bays in area are to be provided with a suitable gully or drainage channel to prevent water damaging the highway.
- Where a driveway falls towards a dwelling it shall be provided with a suitable gully or drainage channel to prevent water damaging the driveway.
- The invert level of a rodding eye at the head of a surface water drain is to be set 450mm below finished ground level unless shown otherwise.
- The maximum depth of both foul and storm access chambers is 600mm below finished ground level.
- The invert level of an access chamber on a foul drain from a building is to be set in accordance with the following table assuming a 450mm floor construction thickness and 140 fall to inspection chamber which must be confirmed prior to construction.

Maximum Length of Connection	8m	11m	14m	17m	20m
Minimum Invert Depth below FFL	100mm	100mm	100mm	100mm	100mm

Inspection Chamber to be used for connections longer than 12m as shown in Part H.

SHEET LAYOUT SCALE = 1:8000

Drainage Legend:

General

- 140.00 Proposed Finished Floor Level
- 139.85 Proposed Garage Slab Level
- Site Boundary

Private Drainage

- Foul Water Sewer (1000mm unless otherwise stated)
- Storm Water Sewer (1000mm unless otherwise stated)
- Foul Water 525mm Inspection Chamber (Max. Depth 3000mm)
- Storm Water 525mm Inspection Chamber (Max. Depth 3000mm)
- Foul Water 300mm Inspection Chamber (Max. Depth 500mm)
- Storm Water 300mm Inspection Chamber (Max. Depth 500mm)
- Foul Water Backdrop (Incoming Invert Level)
- Storm Water Backdrop (Incoming Invert Level)
- Foul Water Pipe Diameter
- Storm Water Rodding Eye & Level
- App Drain
- Storm Water Pipe Diameter
- Dished Channel
- RWP Added
- Yard Gully
- RWP Removed

Adoptable Drainage

- F01 CL:142.00 IL:140.00 S104 FW Sewer & MH (Cover & Invert Levels)
- S02 CL:142.00 IL:140.00 S104 SW Sewer & MH (Cover & Invert Levels)

Rev.	Description	Date	By
1	First Issue	02/02/2022	OB

Drawing Status: **PRELIMINARY**

Subject to Client approval as part of ongoing consultations and design check, amendments may therefore be requested.

Client: **PERSIMMON**
Together, we make a home

Project: **Littlehampton Phase 5**

Title: **Plot Drainage Layout Plan Sheet 3 of 7**

BANNERS GATE
CIVIL, STRUCTURAL & ARCHITECTURAL DESIGN SERVICES
10-11 Birmingham Street, Halesowen, West Midlands B63 3HN
Tel: 0121 687 1500 Fax: 0121 687 1501
E-mail: mail@bannersgate.com

Scale	A1 @ 1:250	Drawn	OB
Date	January 2022	Checked	
File	21044 / dwg / civils / current	Drawing	

21044 / 123