




From: Egan, Clare [REDACTED]
Sent: 02 August 2017 10:49
To: Anita Gardner
Subject: RE: *EXTERNAL: LU/211/17/DOC - Condition 12 - 6 and 7 Courtwick Park Cottages, Littlehampton

Hi Anita,

Since our submission on the 21 June 2017, we have carried out further soakage testing at Courtwick Park Cottage. Due to the poor infiltration rates, the design has now been amended to remove soakaways.

Please find attached the following information on drainage:

- Drainage layout; drawing number 4485/249 Rev B
- Main drainage construction; drawing number 4485/255 Rev A
- Private drainage construction; drawing number 4485/256 Rev A
- Swale network; dated 02.03.17
- Swale plus cottage site 1 in 100yr plus 30%; dated 02.03.17
- Borehole soakage report; dated 28.07.17
- External works layout; drawing number 4485/250 Rev B
- External works construction details; drawing number 4485/254 Rev A

I trust this information is sufficient, but do let me know if you need anything else.

Thank you,

Clare

Clare Egan BA (Hons), PgDip
Technical Trainee

BDW Southern Counties
(a trading name of BDW Trading Limited)
BDW House, Walnut Tree Close, Guildford, Surrey, GU1 4SW



From: Anita Gardner [REDACTED]
Sent: 25 July 2017 17:08
To: Egan, Clare [REDACTED]
Subject: *EXTERNAL: LU/211/17/DOC - Condition 12 - 6 and 7 Courtwick Park Cottages, Littlehampton

EXTERNAL EMAIL WARNING



Please do not click on LINKS or ATTACHMENTS where you are unsure of its origin. In such cases delete the email.

Dear Miss Egan,

I attach the Engineer's comments in relation to condition 12. Please can you advise if you will be able to submit the additional information requested within the next 14 days. If this is not likely then the discharge of condition will be refused in respect of condition 12.

Regards

Anita Gardner

Anita Gardner | Principal Planner, Directorate of Place, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

<http://www.arun.gov.uk>

NLPG UPRN 100062237016

DX 57406 Littlehampton

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

The sender of this e-mail is a member of the Barratt Developments PLC group of companies, the ultimate parent of which is Barratt Developments PLC (company number 00604574). Barratt Developments PLC is registered in England and Wales with its registered office at Barratt House, Cartwright Way, Forest Business Park, Bardon Hill, Coalville, Leicestershire LE67 1UF, together with its principal subsidiaries BDW Trading Limited (03018173), and Wilson Bowden Developments Limited (00948402). Barratt

Homes, Barratt London and David Wilson Homes are trading names of BDW Trading Limited. This e-mail message is meant only for use by the intended addressee and may contain privileged and/or confidential information. If you have received this message in error please notify us and remove it from your system. Please view our 'Email Addendum v2.0' at www.barrattcommercialsupport.co.uk/barratt-developments-plc-email-a for further details.