

Harry Chalk
Planning and Building Control
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

**Lead Local Flood Authority
Ground Floor
Northleigh
County Hall
Chichester
West Sussex
PO19 1RH**

Date 03 February 2026

Planning Reference: **LU/221/25/DOC**

Site Address: **Land at Toddington Lane Toddington Lane Littlehampton BN17 7PN**

Planning Description: **Approval of details reserved by condition imposed under LU/246/24/PL relating to conditions 8-surface water drainage and 9-maintenance and management of surface water drainage.**

Dear Harry

Thank you for your consultation on the above site. For this consultation, we have reviewed the documents listed in the Annex.

The LLFA have reviewed the documents submitted in relation to Condition 8 and Condition 9, as they relate to drainage. For reference, the conditions are worded as follows:

8. Prior to the commencement of development, full details of the proposed surface water drainage scheme must be submitted and approved in writing by the local planning authority. The detailed design must be based upon and build on the surface water information submitted - Drainage Strategy by Green Structural Engineering, 13/01/2025, Revision 1 and Flood Risk Assessment by Green Structural Engineering, October 2024, Revision 0. The full details submitted for approval shall include:

- 1. Detailed drainage plans conforming to Local Planning Authority guidance,*
- 2. Specifications for all surface water drainage components and associated infrastructure or flow control mechanisms,*
- 3. Any relevant permissions relating to the discharge location, works to watercourses or adoption of the SuDS scheme.*

The scheme shall then be constructed as per the approved plans. No dwelling shall be occupied until the complete surface water drainage system serving that building has been implemented in accordance with the agreed details. The surface water drainage scheme shall remain for the lifetime of the development unless agreed in writing by the Local Planning Authority. The Local Planning Authority shall be granted access to inspect the sustainable drainage scheme for the lifetime of the development.

Reason: In order to comply with Arun Local Plan policies W DM2 and W DM3 and the NPPF.

9. Development shall not commence until full details of the maintenance and management of the surface water drainage system is set out in a site-specific maintenance manual and submitted to, and approved in writing, by the Local Planning Authority. The manual is to include details of financial management and arrangements for the replacement of major components at the end of the manufacturer's recommended design life. Upon completed construction of the surface water drainage system, the owner or management company shall strictly adhere to and implement the recommendations contained within the manual.

Reason: To ensure that the development is satisfactorily drained in accordance with Arun Local Plan policies W DM1, W DM2 and W DM3. It is considered necessary for this to be a pre-commencement condition to ensure that the future maintenance and funding arrangements for the surface water disposal scheme are agreed before construction commences.

The further information submitted sufficiently addresses our previous queries and Drainage Management and Maintenance Plan is appropriate for the proposed drainage strategy and is acceptable in relation to the wording of Condition 9. As such, we have **no objection** to the discharge of **Conditions 8 and Condition 9**.

Yours sincerely,

Mat Jackson
Flood Risk Management Team

[Redacted signature]

Annex

- Drainage Statement prepared by GTA Civils
- Proposed Levels Layout Jan 2026 Rev T1 Drawing no. 13509-1500
- Proposed Drainage Layout Oct 2025 Rev T1 Drawing no. 13509-1600
- Proposed drainage details sheet 1 Jan 2026 Rev T1 Drawing no. 13509-1700
- Proposed drainage details sheet 2 Jan 2026 Rev T1 Drawing no. 13509-1700
- Proposed External Works Layout and Details. Jan 2026 Rev T1 Drawing no. 13509-1800
- Southern Water response

PL- Consultation- West Sussex Lead Local Flood Authority response

Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>



Our priorities...

 Improving the wellbeing of Arun	 Delivering the right homes in the right places	 Supporting our environment to support us	 Fulfilling Arun's economic potential	 
---	--	--	---	--

From: [REDACTED]
Sent: 03 February 2026 15:04
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: Application LU/221/25/2

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

FAO Harry Chalk

LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
