

Arun District Council
Development Control
1, Arun Civic Centre Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Our ref: HA/2019/121464/01-L01
Your ref: LU/229/10/
Date: 25 July 2019

Dear Sir/Madam

**APPROVAL OF DETAILS RESERVED BY CONDITION IMPOSED UNDER
LU/229/10/ RELATING TO CONDITION 9-SURFACE WATER DRAINAGE.**


WINDROOS NURSERY WORTHING ROAD LITTLEHAMPTON BN17 6LY

As per our previous response dated 22nd August 2016 the disposal of surface water proposed is via concrete ring soakaways however details of the pollution prevention measures to be utilised have not been supplied. Therefore we are not able to recommend the discharge of this condition.

The Ciria SuDs manual C753 has industry best practice. It provides information and guidance on risk assessment and the likely level of treatment. <http://www.susdrain.org/>.

Yours faithfully

Miss Suz Greenwood
Planning Advisor, Environment Agency



Environment Agency
Canal Walk, ROMSEY, Hampshire, SO51 7LP.

www.gov.uk/environment-agency

End