

From: Laura Gibbons
Sent: 11 March 2019 13:10
To: Planning.Responses
Cc: Andrew Wood
Subject: RE: Planning Consultation on LU/23/19/DOC

Engineers Comments Regarding Condition 10

Infiltration testing and groundwater monitoring has been completed at 5 locations across the site. This is acceptable, and I recommend that condition 10 is discharged.

Because rates vary so greatly I advise that infiltration rates from the closest proximity test should be used in the design of each infiltrating structure. I would also recommend that the applicant refers to our drainage checklist (<https://www.arun.gov.uk/drainagechecklist>) to further understand our requirements for the discharge of condition 9.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 08 March 2019 16:51
To: Land Drainage
Subject: Planning Consultation on LU/23/19/DOC

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO: LU/23/19/DOC

Registered: 24-JAN-19

Site Address: Former Windroos Nursery Worthing Road Littlehampton BN17 6LY

Description of Works: Application for approval of details reserved by conditions imposed on LU/229/10 relating to Condition 10 - Infiltration Rates

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 22nd March 2019.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Andrew Wood who can be contacted on telephone number 01903 737768.

Thanking you in anticipation

Planning Case Officer
Arun District Council

end xxx email

