

Julie Grieves

From: Graham Evans
Sent: 03 November 2011 09:03
To: Planning.Responses
Subject: FW: Planning Consultation on: LU/245/10/

Attachments: 02_ILEGuidance.pdf

No EH objection subject to imposition of condition EHL2 in respect of security lighting. A copy of the ILE Guidance is attached, I would suggest that the application site falls within Environmental Zone E2 - "Low district brightness area" (p3).

A report should be obtained from a suitably qualified (ILE) lighting engineer confirming that the proposed scheme will comply with this Guidance.

Graham Evans
 Senior Environmental Health Officer
 Arun District Council
 01903 737694

From: Sam Humphries
Sent: 02 November 2011 15:34
To: Graham Evans
Subject: FW: Planning Consultation on: LU/245/10/

C/N: 189802

Sam Humphries Administrative Assistant, Corporate Resources Arun District Council Location: Third Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF Internal: 37393 External: +44 (0) 1903 737500 Fax: 01903 730442 E-mail: sam.humphries@arun.gov.uk Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 02 November 2011 13:00
To: EH Planning Consultations
Subject: Planning Consultation on: LU/245/10/

To: **Environmental Health - John Green**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO: LU/245/10/

Registered: 23-DEC-10
Site Address: Land on the west bank of the River Arun Littlehampton

Grid Reference: 502705 101464

Category: Plan Applicat'n

Description of Works: Repositioning of security fencing to boundary of site and security lighting to access road to land on the west bank of the River Arun and construction of additional pontoon moorings.

The Council have received the above planning application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 03-FEB-11. You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on

telephone number 01903 737529.

Thanking you in anticipation

Regards
Planning Case Officer

consultee_email
