Summary of Results for 10 year Return Period (+30%)

Half Drain Time : 23 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
15 min Summer	-1.083	0.417	1.0	1.9	O K
30 min Summer	-1.029	0.471	1.0	2.1	O K
60 min Summer	-1.021	0.479	1.0	2.2	O K
120 min Summer	-1.066	0.434	1.0	2.0	O K
180 min Summer	-1.121	0.379	0.9	1.7	O K
240 min Summer	-1.173	0.327	0.9	1.5	O K
360 min Summer	-1.259	0.241	0.8	1.1	O K
480 min Summer	-1.325	0.175	0.7	0.8	O K
600 min Summer	-1.375	0.125	0.7	0.6	O K
720 min Summer	-1.411	0.089	0.7	0.4	O K
960 min Summer	-1.450	0.050	0.6	0.2	O K
1440 min Summer	-1.463	0.037	0.5	0.2	O K
2160 min Summer	-1.472	0.028	0.3	0.1	O K
2880 min Summer	-1.477	0.023	0.3	0.1	O K
4320 min Summer	-1.483	0.017	0.2	0.1	O K
5760 min Summer	-1.486	0.014	0.2	0.1	O K
7200 min Summer	-1.488	0.012	0.1	0.1	O K
8640 min Summer	-1.490	0.010	0.1	0.0	O K
10080 min Summer	-1.491	0.009	0.1	0.0	O K
15 min Winter	-1.022	0.478	1.0	2.2	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
15 min Summer	70.770	0.0	16
30 min Summer	46.698	0.0	25
60 min Summer	29.629	0.0	42
120 min Summer	18.344	0.0	76
180 min Summer	13.747	0.0	110
240 min Summer	11.169	0.0	142
360 min Summer	8.317	0.0	204
480 min Summer	6.743	0.0	264
600 min Summer	5.728	0.0	322
720 min Summer	5.011	0.0	378
960 min Summer	4.057	0.0	490
1440 min Summer	3.009	0.0	734
2160 min Summer	2.231	0.0	1076
2880 min Summer	1.803	0.0	1464
4320 min Summer	1.335	0.0	2200
5760 min Summer	1.078	0.0	2896
7200 min Summer	0.913	0.0	3592
8640 min Summer	0.798	0.0	4280
10080 min Summer	0.711	0.0	5000
15 min Winter	70.770	0.0	16

©1982-2018 Innovyze

Summary of Results for 10 year Return Period (+30%)

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
30 min Winter	-0.959	0.541	1.1	2.4	O K
60 min Winter	-0.960	0.540	1.1	2.4	O K
120 min Winter	-1.039	0.461	1.0	2.1	O K
180 min Winter	-1.124	0.376	0.9	1.7	O K
240 min Winter	-1.199	0.301	0.8	1.4	O K
360 min Winter	-1.317	0.183	0.7	0.8	O K
480 min Winter	-1.398	0.102	0.7	0.5	O K
600 min Winter	-1.447	0.053	0.6	0.2	O K
720 min Winter	-1.455	0.045	0.6	0.2	O K
960 min Winter	-1.464	0.036	0.5	0.2	O K
1440 min Winter	-1.473	0.027	0.3	0.1	O K
2160 min Winter	-1.480	0.020	0.3	0.1	O K
2880 min Winter	-1.484	0.016	0.2	0.1	O K
4320 min Winter	-1.488	0.012	0.2	0.1	O K
5760 min Winter	-1.490	0.010	0.1	0.0	O K
7200 min Winter	-1.492	0.008	0.1	0.0	O K
8640 min Winter	-1.493	0.007	0.1	0.0	O K
10080 min Winter	-1.493	0.007	0.1	0.0	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
30 min Winter	46.698	0.0	26
60 min Winter	29.629	0.0	46
120 min Winter	18.344	0.0	82
180 min Winter	13.747	0.0	116
240 min Winter	11.169	0.0	148
360 min Winter	8.317	0.0	212
480 min Winter	6.743	0.0	268
600 min Winter	5.728	0.0	314
720 min Winter	5.011	0.0	368
960 min Winter	4.057	0.0	490
1440 min Winter	3.009	0.0	734
2160 min Winter	2.231	0.0	1100
2880 min Winter	1.803	0.0	1436
4320 min Winter	1.335	0.0	2208
5760 min Winter	1.078	0.0	2888
7200 min Winter	0.913	0.0	3552
8640 min Winter	0.798	0.0	4408
10080 min Winter	0.711	0.0	4920

©1982-2018 Innovyze

Rainfall Details

Rainfall Model	FSR	Winter Storms	Yes
Return Period (years)	10	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	19.000	Shortest Storm (mins)	15
Ratio R	0.350	Longest Storm (mins)	10080
Summer Storms	Yes	Climate Change %	+30

Time Area Diagram

Total Area (ha) 0.019

Time (mins) From:	To:	Area (ha)
0	4	0.019

©1982-2018 Innovyze

Model Details

Storage is Online Cover Level (m) 0.000

Trench Soakaway Structure

Infiltration Coefficient Base (m/hr)	0.41760	Trench Width (m)	1.5
Infiltration Coefficient Side (m/hr)	0.41760	Trench Length (m)	10.0
Safety Factor	3.0	Slope (1:X)	0.0
Porosity	0.30	Cap Volume Depth (m)	1.200
Invert Level (m)	-1.500	Cap Infiltration Depth (m)	1.200

©1982-2018 Innovyze