

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Kate Giddings <kate.giddings@arun.gov.uk>
Sent: 31 August 2021 15:53
To: Anita Gardner <Anita.Gardner@arun.gov.uk>
Cc: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: LU/251/21/PL - 57 (47) River Road, Littlehampton, BN17 5DD

Dear Anita,

I hope this e-mail finds you well.

With regard to the above application, please may EH comment as follows:

- No construction activities shall take place, other than between 08.00 hours and 18.0 hours (Monday to Friday) and between 08.00 hours and 13.00 hours (Saturday) with no noisy working activities on Sundays or Bank/Public Holidays. **Reason:** To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031.
- No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to, and approved in writing by, the local planning authority. Thereafter the approved plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters:
 - a. An indicative programme for carrying out of the works
 - b. Details of the arrangements for public engagement / consultation both prior to and continued liaison during the construction works

- c. Measures to minimise the noise (including vibration) generated by the construction process to include hours of work, proposed method of piling for foundations, the careful selection of plant and machinery and use of noise mitigation barrier(s)
- d. Details of any floodlighting, including location, height, type and direction of light sources and intensity of illumination
- e. the parking of vehicles of site operatives and visitors
- f. loading and unloading of plant and materials, including permitted times for deliveries
- g. storage of plant and materials used in constructing the development
- h. the erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate
- i. the provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulations Orders)
- j. measures to control the emission of dust and dirt during construction
- k. a scheme for recycling / disposing of waste resulting from demolition and construction works i.e. no burning permitted

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

- No external lighting shall be installed until details have been submitted to and approved in writing by the relevant planning authority, prior to commencement of the development. This submission shall include a layout plan with beam orientation and a schedule of light equipment (luminaire type, mounting height, aiming angles and luminaire profiles). The approved scheme shall be installed and fully assessed when operational to ensure no light creep/bleed by a competent individual and operated in accordance with the approved details unless the relevant planning authority gives its written consent to the variation.
Reason: To protect the appearance of the area, the environment and wildlife and local residents from light pollution.
- Prior to the commencement of the development hereby approved, a scheme to demonstrate that the internal noise levels within the residential units will conform to the 'Indoor ambient noise levels for dwellings' guideline values specified within Table 4 under section 7.7.2 of BS 8233:2014. Details compiled by a competent acoustician on sound insulation and noise reduction for buildings shall be submitted to and approved in writing by the relevant planning authority. The scheme should take into account the correct number of air changes required for noise affected rooms. The works specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter. **Reason:** To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031.
- Prior to the commencement of the development hereby approved, a scheme to demonstrate that the external noise levels within the curtilage of the residential units will conform to the 'Design criteria for external noise' upper guideline value of 55 dB L_{Aeq, 7} as specified within section 7.7.3.2 of BS 8233:2014. Guidance on sound insulation and noise reduction for proposed developments shall be submitted to and approved in writing by the relevant planning authority. The work specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter. **Reason:** To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031.

- Prior to the commencement of the use hereby approved, a scheme for the provision of facilities to enable the charging of electric vehicles to serve the approved development shall be submitted to the local planning authority for approval and thereafter implemented in accordance with the approved details and the charge points shall thereafter be permanently retained and maintained in good working condition. **Reason:** New petrol and diesel cars / vans will not be sold beyond 2040 and to mitigate against any potential adverse impact of the development on local air quality, in accordance with policy QE DM3 (c) of the Arun Local Plan, the Arun District Council Electric Vehicle Infrastructure Study (November 2017) and the National Planning Policy Framework (NPPF).
- Prior to commencement of the development hereby approved (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved in writing by the Local Planning Authority:
 1. A Preliminary Risk Assessment which has identified: all previous (historical) uses; potential contaminants associated with those uses; a conceptual model of the site indicating sources, pathways and receptors; and potentially unacceptable risks arising from contamination at the site.
 2. A Site Investigation Scheme, based on (1) above to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
 3. Based on the Site Investigation Scheme and the detailed risk assessment (2), an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
 4. A Verification Report providing details of the data that will be collected in order to demonstrate that the works set out in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Note: Any changes to these components, (1) to (4) require the express written consent of the Local Planning Authority.

The scheme shall be implemented as approved above and, prior to commencement of any construction work (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), a Verification Report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of that remediation shall be submitted to and approved in writing by the Local Planning Authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. The report shall also include a 'long-term monitoring and maintenance plan' for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action, as identified in the verification report, and for the reporting of this in writing to the Local Planning Authority. **Reason:** To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

- The owner(s) of any commercial property (warehouses, offices, etc.) built before 2000 are legally obliged to hold a copy of an asbestos register for each property in their portfolio. As the proposed development is being renovated into residential use, the Council needs to be satisfied that if any asbestos previously identified is still present, it is either removed or

suitably managed to minimise risk to human health as there is no safe threshold for asbestos exposure. A copy of the asbestos register and any remedial strategy (where appropriate) must be provided in writing to the Local Planning Authority, prior to any works commencing. **Reason:** To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 - 2031

Informatives:

- The applicant's attention is drawn to the requirements of the Environmental Protection Act 1990 and the Clean Air Act 1993 with regard to burning on site. A statutory nuisance may be caused by smoke and ash from fires or noise from the cutting or chipping trees. In addition, air quality could be adversely affected on large projects. The granting of this planning permission does not permit a statutory nuisance to be caused. The Environment Agency should also be contacted regarding Exemption Permits to burn on site.

Many thanks,

Kate.

Kate Giddings
Senior Technical Officer
Environmental Health

T: 01903 737586

E: kate.giddings@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

