



From: Richard Castro-Parker <Richard.Castro-Parker@arun.gov.uk>
Sent: 07 November 2019 09:25
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: RE: Yeomans Honda consultee comments.

Please could this email EOT agreement be added to the system for LU/252/19/PL.

They are agreeing an EOT till the end of the week which is the 8/11/2019

Thank you

Richard Castro-Parker
Senior Planning Officer (Contract)
Arun District Council

From: Richard Castro-Parker
Sent: 07 November 2019 09:23
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: Yeomans Honda consultee comments.

Please could the EOT agreement be added to the system for LU/252/19/PL.

Thank you

Richard Castro-Parker
Senior Planning Officer (Contract)
Arun District Council

From: Guy Storey [REDACTED]
Sent: 06 November 2019 17:21
To: Juan Baeza <Juan.Baeza@arun.gov.uk>
Cc: Richard Castro-Parker <Richard.Castro-Parker@arun.gov.uk>
Subject: RE: Yeomans Honda consultee comments.

Dear Mr Baeza

I can confirm that an EOT until the end of the week will be fine. Sorry our emails passed.

Best regards

Guy Storey

From: Juan Baeza <Juan.Baeza@arun.gov.uk>
Sent: 06 November 2019 17:17
To: Guy Storey [REDACTED]
Cc: Richard Castro-Parker <Richard.Castro-Parker@arun.gov.uk>
Subject: RE: Yeomans Honda consultee comments.

Dear Mr Storey

Mr Castro-Parker has produced the report recommending approval and is waiting for me. I have just come out of committee and can now turn to delegated reports. Can you please excuse me and agree to an EOT to the end of this week?

Regards

Juan Baeza Area Team Leader – Planning Department, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37765 | External: +44 (0) 1903 737765 | E-mail: juan.baeza@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Guy Storey [REDACTED]
Sent: 06 November 2019 15:09
To: Richard Castro-Parker <Richard.Castro-Parker@arun.gov.uk>
Cc: Juan Baeza <Juan.Baeza@arun.gov.uk>
Subject: RE: Yeomans Honda consultee comments.

Dear Mr. Castro-Parker

I would be grateful if you could provide an update on the above application as our agreed extension of time expires today.

Yours sincerely

Guy Storey
GRS Architects Limited

From: Richard Castro-Parker <Richard.Castro-Parker@arun.gov.uk>
Sent: 04 November 2019 18:19
To: Guy Storey [REDACTED]
Cc: Juan Baeza <Juan.Baeza@arun.gov.uk>
Subject: RE: Yeomans Honda consultee comments.

Dear Mr Storey,

I will look at your comments tomorrow and I will update you as to whether they deal with the matters raised. Thank you for your swift reply.

Yours sincerely

Richard Castro-Parker
Senior Planning Officer (Contract)
Arun District Council

From: Guy Storey [REDACTED]
Sent: 04 November 2019 18:07
To: Richard Castro-Parker <Richard.Castro-Parker@arun.gov.uk>
Cc: Juan Baeza <Juan.Baeza@arun.gov.uk>; James Smith [REDACTED]
Subject: RE: Yeomans Honda consultee comments.

Dear Mr. Castro-Parker

Thank you for your email. I can confirm, as requested, the following:-

That the area was suitably remediated as part of the Permitted change from petrol filling to forecourt. The fuel tanks were slurry/grout filled. The tanks are still in place and would be in the area now being changed in terms of levels and so it would definitely be unwise to disturb and/or infiltrate to the ground in this area, both for the existence of the tanks and for any pollutants that may exist outside of the immediate tank area. I would point out again that the ground will not be broken to ensure that any potential pollutants will not be disturbed.

The discharge to main sewer was a requirement of the previous conversion, where the car washing effluent was required to go to the sewer with a commercial trade effluent discharge licence from Southern Water.

There is no change in impermeable area (and therefore volume) being discharged to the sewer.

The new channel drains will be connected via the same arrangements as previously.

As part of the works I can confirm that the existing on site drainage will be fully cleaned to ensure that it is operating correctly & that no direct discharge to the highway will occur.

The applicant has an ongoing drainage management plan whereby the drainage system & in particular the drainage channels are cleared of any silt or vegetation on an annual basis. I think that an advisory note requiring that the Applicant must ensure that no direct discharge to the highway occurs would be acceptable as is an existing requirement of the site operation.

I can confirm that none of the works will take place on the public highway.

I hope that I have addressed all of the points raised.

Yours Sincerely

Guy Storey
GRS Architects Limited

From: Richard Castro-Parker <Richard.Castro-Parker@arun.gov.uk>
Sent: 04 November 2019 14:05
To: Guy Storey [REDACTED]
Cc: Juan Baeza <Juan.Baeza@arun.gov.uk>
Subject: Yeomans Honda consultee comments.

Dear Mr Storey,

Following my return from annuals leave and sick leave. I note both the Drainage Engineer's and the Highway Officer's Comments as follows:

Further Engineers' Comments received 1/11/2019

It would seem that the area was suitably remediated as part of the Permitted change from petrol filling to forecourt some years ago (the Applicant informs me that the fuel tanks were slurry/grout filled). The tanks are still in place and would be in the area now being changed in terms of levels and so it would be unwise to disturb and/or infiltrate to the ground in this area, both for the existence of the tanks and for any pollutants that may exist outside of the immediate tank area.

The flow to main sewer (mentioned in my previous message) would seem to have been a requirement of the previous conversion, where the car washing effluent was required to go to the sewer with a commercial licence from Southern Water. There is no change in impermeable area (and therefore volume) being discharged to the sewer.

Therefore, if it can be shown that all of the above is correct with the new channel drains being connected via the same arrangements as previously and Southern Water have no concern regarding the revised arrangement, I have no objection to the proposals. It would be worthwhile ensuring a management plan was in place to ensure that the channel drains were cleaned out on a sufficient frequency so as to avoid the risk of direct discharge to the highway.

Highway Officers Comments received 30/10/2019

In principle, the Local Highway Authority (LHA) has no concerns with the proposed works, however the applicants needs to ensure that none of the works will be within the extent of public highway. There seems to be some inconsistencies between the existing features on the proposed plan and what is present on the ground. The block plan demonstrates the existing slot drain at southern access aligns with the existing dwarf wall. This does not seem to be the case on the ground. This makes it difficult to establish if any of the proposed works, namely at the southern access point, will take place on the public highway.

The LHA would ask this is clarified by the applicant, so that suitable informative can be provided if required.

I draw your attention that both the Drainage Engineer and the Highways Officer do not object subject to further clarification of details, as detailed above. Therefore, please could you clarify the above matters. Also of note, is that the Drainage Engineer is recommending a management plan is put in place in place (with any approval) to ensure that the channel drains were cleaned out on a sufficient frequency so as to avoid the risk of direct discharge to the highway. Do you agree to a management plan and a condition requiring one be applied to any grant of planning permission.

I look forward to you reply to this email regarding the above matters.

Yours sincerely

Richard Castro-Parker
Senior Planning Officer (Contract)
Arun District Council

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<https://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
