[redacted]

From: Matthew Kennett
Sent: 26 August 2010 11:26
To: Planning.Responses; Eve Hearsey
Subject: RE: LU/255/10 - Littlehampton Academy

Environmental Health makes the following comments on this application;

We do not object to the application as the site investigation Ref: 16417/GE/**R11** indicates there is no risk to the development of the access road.

The site investigation Ref: 16417/GE/**R10** of the school buildings indicates there is further reliable monitoring for VOCs required, along with the removal of the in situ pipe work in the former tank area. This work will require validation sampling after removal and therefore it is appropriate to apply conditions ENV 5 and 6 to any approval.

Please apply ENV 5 and 6.

Matthew Kennett
Pollution Officer
Environmental Health
Arun District Council
[redacted]
Civic Centre, Maltravers Road, Littlehampton BN17 5LF
For further information on Environmental Health's services visit our website: www.arun.gov.uk/eh