

[REDACTED]

[REDACTED]

From: Hugh Milner [REDACTED]
Sent: 22 October 2019 16:30
To: Andrew Wood <Andrew.Wood@arun.gov.uk>
Cc: Kate Giddings <kate.giddings@arun.gov.uk>; Rob McAlees [REDACTED] Steve Bates
[REDACTED] jaskew [REDACTED]
Subject: Re: LU/299/19/PL - Upgrade of football pitch floodlights at Littlehampton Town Football Club

Dear Mr. Wood,

Attached to the planning application were two floodlighting survey charts that set out the maintained horizontal lux levels of the existing floodlighting configuration and the maintained horizontal lux levels of the proposed installation. The requirements of the Football Association state that the illumination levels shall be recorded on the horizontal plane at ground level, using a self levelling tripod not more than 12 inches above the ground. Readings are required to on a grid of 88 markings (8 across and 11 down) evenly spaced with the outside readings falling on the pitch boundary line. The average of all the readings is taken to be the average illumination level in lux of the floodlighting illumination.

I trust that Kate Giddings will have copies of the floodlighting survey charts mentioned above.

In the mean time I will seek the advice of the Contractors - Sports Lighting of Brixham.

Kind regards

Hugh Milner

On 22 October 2019 at 14:50 Andrew Wood <Andrew.Wood@arun.gov.uk> wrote:

Mr. Milner,

LU/299/19/PL - Upgrade of football pitch floodlights at Littlehampton Town Football Club

Environmental Health team have requested the following condition be applied to the application.

Prior to construction, the horizontal luminance levels on the playing surface/arena shall be submitted to and approved in writing by the Local Planning Authority. The horizontal luminance levels shall be no greater than levels specified for the particular sport/activity and for the level of competition as specified within BS 12193:2018 'Light and Lighting – Sports Lighting'.

Reason: *In the interests of the amenities of neighbouring light-sensitive development.*

This would involve submitting a further application to discharge the condition which I am sure you would wish to avoid. Could you please get the information required from your suppliers and submit the information to me so that it can be agreed by our Environmental Health Officer Kate Giddings who I have copied into this email.

Andrew Wood MRTPI | Senior Planning Officer, Planning Department, Arun District Council |

Location: 1st Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37768 | External: +44 (0) 1903 737768 | E-mail: andrew.wood@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
