

Bronte Welham

From: Amanda Scholes on behalf of Planning.Responses
Sent: 28 March 2018 08:37
To: Planning Scanning
Subject: FW: LU/29/18/CLP 30 Griffin Crescent, Littlehampton

From: Ross Leal
Sent: 26 March 2018 14:04
To: Planning.Responses
Subject: FW: LU/29/18/CLP 30 Griffin Crescent, Littlehampton

Please upload to application.

(At present I am in the office Monday to Thursday. I am not in the office on Fridays).

Ross Leal, DipTP, MRTPI
Senior Planning Officer, Development Management, Directorate of Place, Arun District Council
Location: Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk P Save the environment - think before you print.

Sent: 22 March 2018 14:16
To: Ross Leal
Subject: LU/29/18/CLP 30 Griffin Crescent, Littlehampton

Dear Mr Leal,

Further to your phone call, I confirm that

- a) facing materials to be used in the works that are the subject of the application are to be of a similar appearance to the equivalent existing materials used to form no 30 Griffin Crescent, and
- 2) the proposed roof windows are not to project more than 0.15 metres above the plane of the existing roof surface.

I hope this answers all your queries, if you require further information do please contact me.

Yours truly,

--

Rod Brown