

**Daun Johnson**

---

**From:** Simon Power  
**Sent:** 18 December 2009 15:41  
**To:** Planning.Responses; Anita Gardner  
**Cc:** Brian Holland  
**Subject:** RE: Planning Consultation on: LU/304/09/

[Engineers \(Drainage\) comments;](#)

The applicant states that surface water is to be disposed to a main sewer. However there are no public surface water sewers available in the vicinity. How does the applicant propose to dispose of surface water ?

If soakaways are proposed, then please condition using standard planning condition ref; ENGD3

SP

---

**From:** Brian Holland  
**Sent:** 20 November 2009 13:27  
**To:** Simon Power  
**Subject:** FW: Planning Consultation on: LU/304/09/

[Simon](#)  
[Have you received this one?](#)

BH

---

**From:** [planning.responses@arun.gov.uk](mailto:planning.responses@arun.gov.uk) [mailto:[planning.responses@arun.gov.uk](mailto:planning.responses@arun.gov.uk)]  
**Sent:** 19 November 2009 17:31  
**To:** Brian Holland  
**Subject:** Planning Consultation on: LU/304/09/

**To: Engineering Services Manager**

**NOTIFICATION FROM ARUN DISTRICT COUNCIL**

**TOWN AND COUNTRY PLANNING ACT 1990**

**APPLICATION NO:** LU/304/09/

**Registered:** 19-NOV-09  
**Site Address:** New Cottage Toddington Lane Wick Littlehampton BN17 6JT

**Grid Reference:** 503284 103508

**Category:** Plan Applicat'n

**Description of Works:** Demolition of existing dwelling and garage and redevelopment to provide 4no. 3 bedroom houses and 2no. 4 bedroom houses with new access off Toddington Lane.

---

The Council have received the above planning application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 24-DEC-09. You can also monitor the progress of this application through the Council web site:

[www.arun.gov.uk/planning](http://www.arun.gov.uk/planning)

**Please be aware that any comments you may make will be available on our website.**

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on

telephone number 01903 737529.

Thanking you in anticipation

Regards  
Planning Case Officer

consultee\_email

---