

From: Michael Eastham <Michael.Eastham@arun.gov.uk>
Sent: 22 January 2020 08:33
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: LU/305/19/RES

Please upload the email below, which is a consultation response from Environmental Health, onto Ocella for LU/305/19/RES.

Thanks,

Michael

From: Carol Reynolds <Carol.Reynolds@arun.gov.uk>
Sent: 21 January 2020 16:41
To: Michael Eastham <Michael.Eastham@arun.gov.uk>
Subject: RE: LU/305/19/RES

Dear Michael.

Environmental Health: Apartment Building A has been re-orientated in line with my request, 9th January 2020. The rear facade of this building, as previously described, will now face the intended By Pass to reduce the impact of noise on these flats and to also improve the outlook for the lower level flats. I therefore agree with this proposal. Mitigation in the form of acoustic glazing and mechanical means of acoustic ventilation is nevertheless still likely to be required.

Kind regards
Carol

Carol Reynolds | Senior Environmental Health Officer, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37678 | External: +44 (0) 1903 737678 | E-mail: carol.reynolds@arun.gov.uk Secure E-mail: creynolds@arun.gcsx.gov.uk Visit Arun's web site at www.arun.gov.uk P Save the environment - think before you print.

Please note my Work Days are Tuesday to Friday

From: Michael Eastham <Michael.Eastham@arun.gov.uk>
Sent: 21 January 2020 14:14
To: Carol Reynolds <Carol.Reynolds@arun.gov.uk>
Cc: Christopher Davis <Christopher.Davis@arun.gov.uk>
Subject: FW: LU/305/19/RES
Importance: High

Hi Carol,

EMAIL 1 OF 4

Please find attached the revised plans including the re-orientated apartment building A on Parcel A2.

I look forward to receiving your consultation response to LU/305/19/RES.

Kind regards,

Michael