

-----Original Message-----

From: Anita Gardner

Sent: 21 November 2017 14:24

To: Planning.Responses

Subject: FW: Beach shelter Toilets - Planning application LU/307/17/PL

Please treat as a consultation response from environmental health

Anita Gardner | Principal Planner, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk Visit Arun's web site at www.arun.gov.uk P Save the environment - think before you print.

-----Original Message-----

From: Anna Appleton

Sent: 21 November 2017 14:14

To: 'Jamie Hawkins'

Cc: Anita Gardner; Carol Reynolds; Phil Graham

Subject: RE: Beach shelter Toilets - Planning application LU/307/17/PL

Dear Jamie

Having reviewed the plans with Phil Graham I can confirm that providing the number of customers is limited to a maximum of 200 then the proposals set out for the sanitary convenience are adequate, i.e. 2 female WC's with wash hand basins, 1 male wc and 2 urinals with wash hand basins and 1 unisex wc with wash hand basin.

Regards

Anna Appleton

Anna Appleton | Environmental Health Team Leader, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37676 | External: +44 (0) 1903 737676 | E-mail: anna.appleton@arun.gov.uk Secure E-mail: aappleton@arun.gcsx.gov.uk Visit Arun's web site at www.arun.gov.uk P Save the environment - think before you print.

-----Original Message-----

From: [REDACTED]

Sent: 21 November 2017 12:00

To: Anna Appleton
Cc: [REDACTED]
Subject: Beach shelter Toilets

Good Morning Anna,

Phil Graham has given me your email to contact you regarding the toilet amenities at the proposed beach shelter development.

I can confirm for the record that there will not be more than 200 seats in the development. Thankyou for your assistance in this matter.

Many thanks,

Jamie Hawkins
Coastal Coffee Co
[REDACTED]