Nicola Spencer

From: John Green
Sent: 27 March 2009 12:59
To: Planning.Responses
Subject: RE: Planning Consultation on: LU/32/09/

Environmental Health makes the following comments on this application:

Following recent consultations with the applicant and their ventilation engineer, an amended proposal was received illustrating improved odour control measures to the restaurant cooking ranges. I understand this information has now been submitted to the Planning Authority. On the assumption that this information forms part of the application, we raise no objection. These specifications compared against the Defra guidelines, together with the discharge height of the building/stack, should achieve a level of odour control that reduces the risk of an odour nuisance arising from the discharge of residue cooking odours from these premises. The information on noise levels indicates that no noise nuisance should arise.

Please note that these premises will be required to provide adequate facilities for the storage and collection of refuse and food waste

John Green
Principal Environmental Health Officer
ext 37693

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 04 March 2009 12:00
To: EH Planning Consultations
Subject: Planning Consultation on: LU/32/09/

To: **Environmental Health · John Green**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO:	**LU/32/09/**
Registered:	02-MAR-09
Site Address:	5-7 East Street Littlehampton
Grid Reference:	502891-102140
Category:	Plan Applicat'n
Description of Works:	Alterations to convert existing first floor flat into two self contained flats including external stairs and rear entrance doors, provision of revised kitchen extract flue. Use of ground floor as restaurant

The Council have received the above planning application. I shall be pleased to receive any observations you may wish to make.

Click here to view the application details
Should you have any comments to make, these should be sent by replying to this email by 02-APR-09. You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning
Please be aware that any comments you may make will be available on our website.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mr J Smith who can be contacted on telephone number 01903 737761.

Thanking you in anticipation

consultee_email