

[REDACTED]

[REDACTED]

[REDACTED]

Please treat as additional and substitute

[REDACTED]

[REDACTED]

F.A.O. Anita Gardner,


Please find attached revised drainage design, calculations, drainage report and manufacturer's details for silt traps as requested.

I trust the above is sufficient however should you require any additional information then please do not hesitate to contact me.

Many thanks

Tony Phebey

On behalf of ADCS Ltd



Dear Mr Phebey,

I have received the following consultation response from our Drainage Engineer:

'Please can the applicant submit/clarify the following information:


1. Please provide details of infiltration testing and groundwater monitoring. Including the depth that the infiltration tests were completed to. The proposed soakaway is deeper than the agreed permeable paving.
2. Please submit drawing details for the soakaway and ACO channel, including the appropriate cover depths and levels.
3. Please include the location of pipes and manholes on the Drainage Layout, please label these with their diameters, materials, cover levels, invert levels and falls as appropriate.
4. The calculations have confused the dimensions of the soakaway. The depth is 1m (1000mm) rather than 14776mm. Please adjust accordingly.
5. Please add 40% allowance for climate change.
6. Please provide silt traps upstream of the connection to the soakaway and show these on the drainage layout.

Once this information is submitted to will be possible to reassess the application.'

Accordingly, I will hold the application in abeyance awaiting the provision of the information requested within the next 2 weeks. However if no additional information is received by 04-12-2019 the application will be determined on the basis of the information submitted.

Regards

Anita Gardner



<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
