

30/11/2021

App: LU/352/21/DOC

Proposal: Approval of details reserved by condition imposed under ref LU/331/17/PL relating to Condition No 7 - external lighting/floodlighting.

Address: Land at Lineside Industrial Estate Northwest of Unit 26 Eldon Way Littlehampton BN17 7HE

Condition 7

Thank you for submitting the Lighting Plan for the proposed development. To ensure nocturnal wildlife will not be disturbed we require additional information. Can the applicant please provide information to satisfy us that the following principles have been addressed:

- Luminaires should have warm white spectrum (ideally <2700Kelvin) to reduce blue light component.
- Any external security lighting should be set on motion-sensors and short (1min) timers.
- Accessories such as baffles, hoods or louvres should been used, where necessary, to reduce light spill and direct it only to where it is needed (i.e. away from marginal vegetation).

Kind Regards

Jen



Jennifer Pollitt
Environment Officer
Environment
Chichester District Council

<http://www.chichester.gov.uk>