

From: Jennifer Pollitt [REDACTED]
Sent: 14 December 2021 14:29
To: Amy Myer <Amy.Myer@arun.gov.uk>
Subject: RE: LU/352/21/DOC - Lineside - Ecology request - IMPORTANT

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hi Amy,

I have just looked at the lighting specification and the information produced is not sufficient enough for me to recommend discharging the condition. If the colour of the light cannot be changed for the pole mounted lights then we would be looking for baffles etc. to stop unnecessary light spill from the site. The wall lights could be replaced with something that provides a warmer colour or confirmation of the hours of use, timers etc.

Kind Regards,

Jen



Jennifer Pollitt
Environment Officer
Environmental Strategy
Chichester District Council

[REDACTED]
For all the latest coronavirus and council news, sign up to our monthly email newsletter.

<http://www.chichester.gov.uk/newsalerts>

East Pallant House opening hours: 9am-5pm on Monday, Tuesday, Wednesday and Friday, and 10am- 5pm on Thursday



tion and for other lawful purposes.