Charlotte Burrows

From: John Green
Sent: 18 February 2008 17:17
To: Planning.Responses
Subject: RE: Planning Consultation on: LU/36/08/

Environmental Health makes the following comments on this application:

The drawing submitted for examination does not provide information regarding location and specifications of any proposed extract ventilation system, which would be necessary for potential food operation. We therefore **object** to the application.

Should you permit the application please place a condition requiring a ventilation scheme to be submitted for approval.

Informatives:
There are no indication to the proposed numbers of customer seating in order to assess adequate sanitary accommodation arrangements.

he potential seating numbers on both first & ground floors for consumption of food on these premises would require substantial dry food/refrigerated food storage provision. The dimensions of the kitchen store is minimal, the applicant will need to clarify how adequate food storage facilities can be achieved.

A designated wash up area and/or adequate wash facilities at food areas are not indicated on the layout drawing

John Green
Principal Environmental Health Officer
ext 37693

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 11 February 2008 12:30
To: EH Planning Consultations
Subject: Planning Consultation on: LU/36/08/

To: **Environmental Health - John Green**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO:	**LU/36/08/**
Registered:	08-FEB-08
Site Address:	71 High Street Littlehampton
Grid Reference:	502919-102132
Category:	Plan Applicat'n
Description of Works:	Change of use to A3, A4 & A5

The Council have received the above planning application. I shall be pleased to receive any observations you may wish to make.
Click here to view the application details

Should you have any comments to make, these should be sent by replying to this email by 13-MAR-08. You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning
Please be aware that any comments you may make will be available on our website.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mr M Porter who can be contacted on telephone number 01903 737619.

Thanking you in anticipation

consultee_email