



From: Chima Umunnakwe <Chima.Umunnakwe@arun.gov.uk>
Sent: 10 February 2022 17:22
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: LU/382/21/PL

Dear Planning,

I have considered the above application an Environmental Health recommend the following matter to be considered when deciding this application. Should approval be granted, the recommend EH condition should be imposed.

Noise Assessment

I have reviewed the noise report accompanying this application and I confirm that the assessment has been carried out in accordance with best practice. However, we recommend the following noise conditions to be imposed should approval be granted.

Condition – Sound Insulation

Prior to commencement of the development the applicant shall provide a scheme to the Local Planning Authority for its written approval detailing sound transmission reduction measures to be installed within the ceiling for the proposed commercial use. The scheme shall be designed to be 5dB better than that given in Approved Document E (2003 Edition incorporating 2004 and 2010 amendments) of the Building Regulations (Table 0.1a, page 12). Once agreed in writing by the Local Planning Authority the approved details shall be installed prior to the development being occupied and retained thereafter.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Plant Noise condition

Prior to the first use of the premises, details of any plant (including ventilation, refrigeration and air conditioning) and / or ducting system to be used and the method of control of noise and vibration of this plant shall be submitted to and approved in writing by the Local Planning Authority. The development shall be carried out in accordance with the approved details. The scheme shall ensure that the noise and vibration generated at the boundary of any noise sensitive property shall not exceed Noise Rating Curve: NR35 as defined within Table B.1: Noise Rating Values of BS 8233:2014.

The equipment installed and commissioned shall be maintained in a condition and operated in compliance to the approved scheme whenever it is operation so that it does not exceed NR35 as described above, whenever it's operating. After installation of the approved plant, no new plant or ducting system shall be used without the prior written consent of the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Post Construction Validation

An acoustic assessment of compliance with the noise conditions shall be submitted to the Local Planning Authority no later than two months after completion of the development hereby permitted. This will particularly consider those properties which are nearest to identified sources of commercial or industrial noise or any major road. Any provisions indicated in the assessment which need to be made to control noise effecting the site pursuant to the said conditions, shall be submitted in writing for the written approval of the Local Planning Authority within 1 month of the assessment and all works which form part of the approved scheme shall thereafter be implemented in accordance with a timetable to be agreed in writing by the Local Planning Authority and thereafter maintained.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Land Contamination

Prior to commencement of the development hereby approved (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved in writing by the Local Planning Authority:

1. A Site Investigation Scheme, based on previous preliminary risk assessment to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
2. Based on the Site Investigation Scheme and the detailed risk assessment (1), an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
3. A Verification Report providing details of the data that will be collected in order to demonstrate that the works set out in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Note: Any changes to these components, (1) to (4) require the express written consent of the Local Planning Authority.

The scheme shall be implemented as approved above and, prior to commencement of any construction work (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), a Verification Report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of that remediation shall be submitted to and approved in writing by the Local Planning Authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. The report shall also include a long-term monitoring and maintenance plan for longer-term monitoring of pollutant linkages, maintenance and arrangements

for contingency action, as identified in the verification report, and for the reporting of this in writing to the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

Construction Management

No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to, and approved in writing by, the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters:

- a) An indicative programme for carrying out of the works;
- b) Details of the arrangements for public engagement / consultation both prior to and continued liaison during the construction works;
- c) Measures to minimise the noise (including vibration) generated by the construction process to include hours of work, proposed method of piling for foundations, the careful selection of plant and machinery and use of noise mitigation barrier(s);
- d) Details of any floodlighting, including location, height, type and direction of light sources and intensity of illumination;
- e) The parking of vehicles of site operatives and visitors;
- f) Loading and unloading of plant and materials, including permitted times for deliveries;
- g) Storage of plant and materials used in constructing the development;
- h) The erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate;
- i) The provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulations Orders);
- j) Measures to control the emission of dust and dirt during construction;
- k) A scheme for recycling / disposing of waste resulting from demolition and construction works i.e. no burning permitted.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Regards

Chima Umunnakwe
Environmental Protection Officer
Technical Services

T: 01903 737336

E: chima.umunnakwe@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Due to the current pandemic, work is being prioritised according to public safety risks and you may not receive an immediate response to your email. Wherever possible we will endeavour to respond within 7 working days.

The Environmental Health Team in particular are focused on supporting COVID-19 compliance, and other services may be limited or delayed. Further details of our current service levels can be found at: <https://www.arun.gov.uk/service-status>

If you are making contact for advice or to register a new request for service, including enquiries about COVID-19, food safety, noise or pollution, you can register these directly on-line at <https://eh.arun.gov.uk/>

