

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter [here](#)



From: Chima Umunnakwe <Chima.Umunnakwe@arun.gov.uk>

Sent: 10 February 2022 12:11

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Cc: Obafemi Okusipe <Obafemi.Okusipe@arun.gov.uk>

Subject: LU/411/21/PL

Dear Planning ,

I have considered the above application and can advise that should planning approval be granted, the following consideration should be given.

Sound Insulation Scheme

Prior to the commencement of the development hereby approved, a scheme to demonstrate that the internal noise levels within the residential units will conform to the 'Indoor ambient noise levels for dwellings' guideline values specified within Table 4 under section 7.7.2 of BS 8233:2014 and shall be complied by a competent acoustician on sound insulation and noise reduction for buildings and shall be submitted to and approved in writing by the Local Planning Authority. The scheme should take into account the correct number of air changes required for noise affected rooms. The works specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Construction hours

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

[In addition to these hours of working, the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of The Adopted Arun Plan 2011 – 2031

Plant Noise assessment

Details, including acoustic specifications, of all fixed plant, machinery and equipment associated with air moving equipment, compressors, generators or plant or equipment of a like kind, installed within the site which has the potential to cause noise disturbance to any noise sensitive receivers, shall be submitted to and approved by the Local Planning Authority before installation. The rating level of noise emitted from the use of this plant, machinery or equipment shall not exceed the measured background sound level when assessed by a competent acoustician using BS 4142:2014, at any adjoining or nearby noise sensitive premises.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

External lighting

Prior to the commencement of the development, details of the external lighting of the site shall be submitted to and approved in writing by the Local Planning Authority. These details shall include the predictions of both horizontal illuminance across the site and vertical illuminance affecting immediately adjacent receptors. The lighting installation shall comply with the recommendations of the Institution of Lighting Professionals (ILP) 'Guidance Notes for the Reduction of Obtrusive Light' (GN01:2011)

Reason: To protect the amenity of local residents in accordance with Policy QE DM2 of the Adopted Arun Local Plan 2011 – 2031

Regards

Chima Umunnakwe
Environmental Protection Officer
Technical Services

T: 01903 737336
E: chima.umunnakwe@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Due to the current pandemic, work is being prioritised according to public safety risks and you may not receive an immediate response to your email. Wherever possible we will endeavour to respond within 7 working days.

The Environmental Health Team in particular are focused on supporting COVID-19 compliance, and other services may be limited or delayed. Further details of our current service levels can be found at: <https://www.arun.gov.uk/service-status>

If you are making contact for advice or to register a new request for service, including enquiries about COVID-19, food safety, noise or pollution, you can register these directly on-line at <https://eh.arun.gov.uk/>

