

Arun District Council
Development Control
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Our ref: HA/2022/123867/03-L01
Your ref: LU/411/21/PL
Date: 10 May 2022

Dear Planning Team,

FURTHER INFORMATION SUBMITTED BY EMAIL 22 APR 2022 - CHANGE OF USE FROM EXISTING LEISURE USE TO 10NO. 1-BEDROOM 1 PERSON SUPPORTED LIVING APARTMENTS, STAFF OFFICE, STAFF SLEEPOVER, AND ASSOCIATED ANCILLARY FACILITIES TO INCLUDE EXTENSION TO FORM NEW FIRST FLOOR, ALTERATIONS TO ROOF SPACE INCLUDING CREATION OF DORMER WINDOWS & INSTALLATION OF ROOF LIGHTS.

90-91 SOUTH TERRACE, LITTLEHAMPTON, WEST SUSSEX, BN17 5LJ.

Thank you for consulting the Environment Agency on the above application.

We have reviewed the information as submitted and set out our position below.

Environment Agency Position

Condition

The development shall be carried out in accordance with the submitted Flood Risk Assessment (dated 05/01/2022) and the following mitigation measures it details:

- Finished floor levels shall be set no lower than 5m above Ordnance Datum (AOD).

These mitigation measures shall be fully implemented prior to occupation and subsequently in accordance with the scheme's timing/phasing arrangements. The measures detailed above shall be retained and maintained thereafter throughout the lifetime of the development.

Reason

Environment Agency
Guildbourne House Chatsworth Road, Worthing, West Sussex, BN11 1LD.
Customer services line: [REDACTED]
www.gov.uk/environment-agency

Cont/d..

To reduce the risk of flooding to the proposed development and future occupants.

Advice to LPA/Applicant

Flood Proofing

We strongly recommend the use of flood proofing and resilience measures. Physical barriers, raised electrical fittings and special construction materials are just some of the ways you can help reduce flood damage.

To find out which measures will be effective for this development, please contact your building control department. In the meantime, if you'd like to find out more about reducing flood damage, visit the flood risk and coastal change pages of the planning practice guidance. The following documents may also be useful:

Department for Communities and Local Government: Preparing for floods

<http://www.planningportal.gov.uk/uploads/odpm/4000000009282.pdf>

Department for Communities and Local Government: Improving the flood performance of new buildings:

<http://www.communities.gov.uk/publications/planningandbuilding/improvingflood>

We do not normally comment on or approve the adequacy of flood emergency response procedures accompanying development proposals, as we do not carry out these roles during a flood. Our involvement with this development during an emergency will be limited to delivering flood warnings to occupants/users covered by our flood warning network.

The planning practice guidance to the National Planning Policy Framework states that, in determining whether a development is safe, the ability of residents and users to safely access and exit a building during a design flood and to evacuate before an extreme flood needs to be considered. One of the key considerations to ensure that any new development is safe is whether adequate flood warnings would be available to people using the development.

In all circumstances where warning and emergency response is fundamental to managing flood risk, we advise local planning authorities to formally consider the emergency planning and rescue implications of new development in making their decisions. As such, we recommend you consult with your emergency planners and the emergency services to determine whether the proposals are safe in accordance with the guiding principles of the Planning Practice Guidance (PPG).

Please do not hesitate to contact me using the contact details shown below should you have any queries regarding the above information.

Yours faithfully

Mrs Sophie Brown
Sustainable Places Planning Advisor



Cont/d..

