

Bronte Welham

From: Amanda Scholes on behalf of Planning.Responses
Sent: 29 January 2018 08:10
To: Planning Scanning
Subject: FW: Planning Consultation on LU/426/17/DOC

From: Carol Reynolds
Sent: 26 January 2018 17:30
To: Planning.Responses
Subject: FW: Planning Consultation on LU/426/17/DOC

Environmental Health: I note comment by WSCC Highways, 25th January 2018 in that this relates to the proposed acoustic barrier. To reiterate previous comment from this Department, suitable provision must be made for ongoing maintenance of this structure, without which residents may be subject to excessive road noise. The persons who will carry out such ongoing maintenance work should be specified and suitable arrangements put in place to allow proper access for this purpose. The barrier must be imperforate, continuous and/or overlapping, notwithstanding existing trees/planting.

C/N: 222390

Samantha Humphries | Administrative Assistant, Corporate Support
Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk Save the environment - think before you print.

Sent: 11 January 2018 08:49
To: EH Planning Consultations
Subject: Planning Consultation on LU/426/17/DOC

To: Environmental Health - Anna Appleton

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO: LU/426/17/DOC

Registered: 22-DEC-17
Site Address: Fitzalan Link Road Littlehampton

Description of Works: Approval of details reserved by condition imposed under LU/234/16/RES relating to condition 7 for details of acoustic barrier.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 25th January 2018.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Michael Eastham who can be contacted on telephone number [REDACTED]

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
