

South Eastern Power Networks plc  
Newington House  
237 Southward Bridge Road  
London  
SW1 6NP

Date: 22nd March 2022

Please ask for: Mrs A Gardner

Tel: 01903 737529

Your Ref:

Our Ref: LU/47/22/OHL

Dear Mr Jackson,

---

Notification under Overhead Lines (Exemption) Regulations 2009 to remove and replace pole 550586 with a 12-metre stout service pole which no longer requires any stays to support itself.  
Rear of 27-33 Beach Road Littlehampton

---

The Local Planning Authority has No Objection to the proposal which seeks consent under Section 37 of the Electricity Act 1989 to install an electric line above ground. It also seeks planning permission for the development under section 90(2) of the Town and Country Act 1990.

The existing equipment raises safety concerns and the proposal has been submitted to remove the existing apparatus and provide a replacement pole with a 12m pole which does not require stays. Consent is sought to dismantle the existing low voltage pole and overhead service. The proposal will upgrade the aerial cable to ensure a 3 phase service and includes raising mounting to the top wall near to the front of the property and reconnecting to the meter on 37-39 Beach Road. The car wash premises has requested their service to be put underground.



Neil Crowther  
Group Head of Planning