

[REDACTED]

From: Kate Giddings
Sent: 08 April 2019 16:45
To: Andrew Wood; [REDACTED]
Cc: Anna Appleton; Planning.Responses
Subject: FW: LU/56/19/DOC - Former Windroos Nursery, Worthing Road, Littlehampton, BN17 6LY

Good afternoon again,

Further to my below e-mail, could the consultant also please confirm whether the footer displayed from p34 in the main body of the report is merely a typographical error, as it reads December 2018, V1.

Many thanks,

Kate Giddings.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road,
Littlehampton, West Sussex, BN17 5LF
Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Kate Giddings
Sent: 08 April 2019 16:43
To: Andrew Wood; [REDACTED]
Cc: Planning.Responses; Anna Appleton
Subject: LU/56/19/DOC - Former Windroos Nursery, Worthing Road, Littlehampton, BN17 6LY

Good afternoon,

Having now reviewed WYG's Interpretative Ground Investigation Report V2 (ref.: A111089, dated February 2019) in relation to the above application, I have the following comments:

- ground gas monitoring was conducted in 2013; due to the age of the data, monitoring should be undertaken to ascertain the current gassing regime of the site in order to determine what, if any, remedial or protection measures are required
- the above report outlines several remedial options; please advise when a strategy has been decided

- Condition 5 cannot be discharged until a suitable and effective remedial strategy has been implemented and (as per the fourth stage of the condition), a verification report provided, to include validation sampling where necessary.

Please note that any remedial measures are likely to include some, if not all, of the following:

- asbestos management plan
- materials management plan
- discovery strategy to address any previously unidentified potential contamination.

The above can be supplied as part of any remediation plan or as stand-alone documents.

Please do not hesitate to make contact using the below details, should the need require.

Kind regards,

Kate Giddings.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road,
Littlehampton, West Sussex, BN17 5LF

Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.