


From: David Innes [REDACTED]
Sent: 11 April 2019 15:36
To: Kate Giddings
Cc: Andrew Wood; Christian O'Brien; [REDACTED] Anna Appleton
Subject: Fwd: LU/56/19/DOC - Former Windroos Nursery, Worthing Road, Littlehampton, BN17 6LY

Hi Kate,

Further to your emails we would like to make the following comments inserted in red following your points below.

I trust that the clarifications and the additional report which was submitted to EH (pollution@arun.gov.uk and Mathew Kennett who had dealt with original submission) on 22 March and the comments below in red allow you to formally discharge the remaining part of condition 5.

I will give you a call tomorrow afternoon to discuss.

Regards

David Innes
[REDACTED]

Good afternoon again,

Further to my below e-mail, could the consultant also please confirm whether the footer displayed from p34 in the main body of the report is merely a typographical error, as it reads December 2018, V1.

This is a typographical error. The correct date for the report is February 2019.

Many thanks,

Kate Giddings.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF

Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Kate Giddings

Sent: 08 April 2019 16:43

To: Andrew Wood; [REDACTED]

Cc: Planning.Responses; Anna Appleton

Subject: LU/56/19/DOC - Former Windroos Nursery, Worthing Road, Littlehampton, BN17 6LY

Good afternoon,

Having now reviewed WYG's Interpretative Ground Investigation Report V2 (ref.: A111089, dated February 2019) in relation to the above application, I have the following comments:

- ground gas monitoring was conducted in 2013; due to the age of the data, monitoring should be undertaken to ascertain the current gassing regime of the site in order to determine what, if any, remedial or protection measures are required

The ground investigation report submitted by WYG was undertaken with the objective of discharging Condition 5 section 3 of the planning condition in response to a letter dated 15th May 2014 from Arun District council which stated that Condition 5 sections 1 and 2 had been met but that further investigation was required to enable a remedial strategy to be finalised following removal of tanks. As section 1&2 are already discharged the focus can, in planning terms, only relate to section 3 of the condition we are seeking to discharge.

- the above report outlines several remedial options; please advise when a strategy has been decided

We prepared a separate remediation strategy for the site in March and this was submitted to EH section using the pollution@arun.gov.uk copy attached for convenience.

- Condition 5 cannot be discharged until a suitable and effective remedial strategy has been implemented and (as per the fourth

stage of the condition), a verification report provided, to include validation sampling where necessary.

The remediation strategy report referenced above addresses these issues, including recommendations for a materials management plan, discovery strategy and requirements for verification reporting. A verification report cannot be submitted to facilitate full discharge of Condition 5 until development works are complete.

Please note that any remedial measures are likely to include some, if not all, of the following:

- asbestos management plan
- materials management plan
- discovery strategy to address any previously unidentified potential contamination.

The above can be supplied as part of any remediation plan or as stand-alone documents.

Please do not hesitate to make contact using the below details, should the need require.

Kind regards,

Kate Giddings.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF
Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk
Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

<http://www.arun.gov.uk>
DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

DISCLAIMER: The information contained in this email is intended for the named recipient only. It may contain privileged and/or confidential information and if you are not an intended recipient you must not copy, distribute or take any action in reliance on it. If you have received this message in error please notify us immediately by email to [REDACTED] Recipients must understand that conclusions, opinions and other information contained in the above email not relating to the official

scope of business of Dandara Group Holdings Limited or associated companies shall be deemed not to have been given or endorsed by Dandara Group Holdings Limited or associated companies.

.....
This message contains confidential information and is intended only for the recipient. If you are not the recipient you should not disseminate, distribute or copy this e-mail. Please notify the sender immediately by e-mail if you have received this e-mail by mistake and delete this e-mail from your system. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors or omissions in the contents of this message, which arise as a result of e-mail transmission. If verification is required please request a hard-copy version.
.....

DISCLAIMER:The information contained in this email is intended for the named recipient only. It may contain privileged and/or confidential information and if you are not an intended recipient you must not copy, distribute or take any action in reliance on it. If you have received this message in error please notify us immediately by email to

██████████ Recipients must understand that conclusions, opinions and other information contained in the above email not relating to the official scope of business of Dandara Group Holdings Limited or associated companies shall be deemed not to have been given or endorsed by Dandara Group Holdings Limited or associated companies.