

Please scan as additional comments from agent

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

REFERENCE EML-OUT/20-007/20200505-165046-945

Hi Anita,

Apologies, Rob Winzar is currently furloughed and your email slipped the net, however I have just caught it again.

In response to your query, the existing cooker and extraction is to remain and if an additional cooker is required by the client there will be a domestic type extract/cooker hood installed to the following specification.

'Kitchen to have mechanical ventilation with an extract rating of 60l/sec or 30l/sec if adjacent to hob to external air, sealed to prevent entry of moisture. Intermittent extract fans to BS EN 13141-4. Cooker hoods to BS EN 13141-3. All fixed mechanical ventilation systems, where they can be tested and adjusted, shall be commissioned and a commissioning notice given to the Building Control Body.'

Please note that this is not a commercial scale kitchen, it is used solely to provide food for the small number of residents.'

If you have any queries please get back to me in lieu of Rob for the time being.

Regards

Chris

Christopher Cook Dip. Arch. RIBA
Architect/Director
Axis Architecture Limited - Chartered Practice



25 YEARS 1994 - 2019

The Old Post Office, Station Road, Wickham, Hampshire PO17 5JA

Do you need to print this email? Please consider your environmental responsibility.

The following refers to email messages transmitted from, or on behalf of, Axis Architecture Limited.

This information contained in any e-mail and their attached files, including replies and forwarded copies, are confidential and intended solely for the addressee(s) and may be legally privileged or prohibited from disclosure and unauthorised use.

If you are not the named addressee you may not use, copy or disclose this information to any other person.

If you received this message in error please notify the sender immediately and delete all copies of the email and associated files.

If you are not the intended recipient, any form of reproduction, dissemination, copying, disclosure, modification, distribution and/or publication or any action taken or omitted to be taken in reliance upon this message or its attachments is prohibited and may be unlawful.

Any views or opinions presented are solely those of the originator and do not necessarily represent those of Axis Architecture Limited

All liability for viruses is excluded to the fullest extent permitted by law.

Dear Mr Winzar,

Please see the e-mail below from the environmental health officer.

I would appreciate confirmation within the next 10 days, that the proposed kitchen extension will not include additional and/or altered extraction/ventilation/air conditioning as a result of the proposal.

Regards

Anita Gardner

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.



Dear Anita,

In relation to the above application, I note that section 20 of the application form has been completed 'N/A'; could the applicant please confirm whether this means that the proposed kitchen extension will not include additional and/or altered extraction/ventilation/air conditioning equipment?

Many thanks,

Kate.



<http://www.arun.gov.uk>
DX 57406 Littlehampton
You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
