




---

**From:** Chima Umunnakwe <Chima.Umunnakwe@arun.gov.uk>  
**Sent:** 06 April 2022 13:02  
**To:** Planning.Responses <Planning.Responses@arun.gov.uk>  
**Cc:** Anita Gardner <Anita.Gardner@arun.gov.uk>  
**Subject:** LU/61/22/PL

Dear Planning,

I refer to the above application for planning consideration and recommend that should approval be granted the following EH comments should be considered.

The application statement submitted that the development is unlikely have result in loss of amenity at the noise sensitive location. However, this statement is not evidence based. Noise is fundamentally a material consideration and we need to have a reasonable degree of certainty that this development will not result in adverse impact on residential noise sensitive receptors. Accordingly, we have recommended the following noise condition.

**Noise control**

No development shall take place before a noise impact assessment has been carried out. Thereafter, a scheme shall be submitted to and approved in writing by the Local Planning Authority, which specifies the provisions to be made for the control of plant and vehicle and low frequency noise emanating from the site. Thereafter, the use of the proposed development shall not commence until the approved scheme has been fully implemented.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

**Construction hours condition**

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

## Construction Management

No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to, and approved in writing by, the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters:

- a) An indicative programme for carrying out of the works;
- b) Details of the arrangements for public engagement / consultation both prior to and continued liaison during the construction works;
- c) Measures to minimise the noise (including vibration) generated by the construction process to include hours of work, proposed method of piling for foundations, the careful selection of plant and machinery and use of noise mitigation barrier(s);
- d) Details of any floodlighting, including location, height, type and direction of light sources and intensity of illumination;
- e) The parking of vehicles of site operatives and visitors;
- f) Loading and unloading of plant and materials, including permitted times for deliveries;
- g) Storage of plant and materials used in constructing the development;
- h) The erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate;
- i) The provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulations Orders);
- j) Measures to control the emission of dust and dirt during construction;
- k) A scheme for recycling / disposing of waste resulting from demolition and construction works i.e. no burning permitted.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

### Informative:

- The applicant's attention is drawn to the requirements of the Environmental Protection Act 1990 and the Clean Air Act 1993 with regard to burning on site. A statutory nuisance may be caused by smoke and ash from fires or noise from the cutting or chipping trees. In addition, air quality could be adversely affected on large projects. The granting of this planning permission does not permit a statutory nuisance to be caused. The Environment Agency should also be contacted regarding Exemption Permits to burn on site.
- The granting of this planning permission does not in any way indemnify against statutory nuisance action being taken should substantiated complaints within the remit of the Environmental Protection Act 1990 be received. For further information, please contact the Environmental Health Department on 01903 737755.

Kind Regards

**Chima Umunnakwe**  
Environmental Protection Officer  
Technical Services

T: 01903 737336  
E: [chima.umunnakwe@arun.gov.uk](mailto:chima.umunnakwe@arun.gov.uk)

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF  
[www.arun.gov.uk](http://www.arun.gov.uk)



Due to the current pandemic, work is being prioritised according to public safety risks and you may not receive an immediate response to your email. Wherever possible we will endeavour to respond within 7 working days.

The Environmental Health Team in particular are focused on supporting COVID-19 compliance, and other services may be limited or delayed. Further details of our current service levels can be found at: <https://www.arun.gov.uk/service-status>

If you are making contact for advice or to register a new request for service, including enquiries about COVID-19, food safety, noise or pollution, you can register these directly on-line at <https://eh.arun.gov.uk/>

